

**Moniteau School District
Maintenance Department
Dassa McKinney Elementary
School**

**Water Treatment Plant
Monthly Operations Report for
August 2020**

Dassa McKinney Elementary School Water Treatment Facility										
Month	Day	PH	Iron	Cl2 Free	Cl2 Total	Hardness	Meter Reading	Operator	Time	Notes
1	Sat									
2	Sun									
3	Mon									
4	Tues									
5	Wed	8.0	0.00	0.43	0.48	1.89	11970800	Jeff R	2:30P	
6	Thurs	8.0	0.01	0.45	0.50	1.94	11972500	Jeff R	2:30P	1700
7	Fri	7.9	0.03	0.48	0.53	1.67	11973800	Jeff R	2:30P	1300
8	Sat									
9	Sun									
10	Mon	7.8	0.02	0.44	0.49	1.72	11974700	Jeff R.	11:30A	900
11	Tues									1300
12	Wed	7.9	0.05	0.72	0.77	1.81	11976000	Jeff R	2:30P	0
13	Thurs	8.0	0.04	0.76	0.81	1.87	11977300	Jeff R.	2:30P	1300
14	Fri	7.9	0.06	0.60	0.65	1.64	11977600	Jeff R.	2:00P	300
15	Sat									
16	Sun									
17	Mon	8.0	0.05	0.41	0.46	1.63	11977700	Jeff R	1:30P	100
18	Tues	7.9	0.03	0.63	0.68	1.65	11978100	Jeff R	2:30P	400
19	Wed	8.0	0.04	0.54	0.57	1.23	11978300	Jeff R.	2:30P	200
20	Thurs	7.9	0.03	0.48	0.53	1.33	11978600	Jeff R	2:30P	300
21	Fri	7.9	0.03	0.45	0.50	1.48	11978700	Jeff R	2:30P	100
22	Sat									
23	Sun									
24	Mon	8.0	0.02	0.84	0.88	1.53	11983600	Jeff R.	2:00P	4900
25	Tues	7.9	0.04	0.62	0.66	1.54	12000200	Jeff R.	3:00P	16600
26	Wed	7.9	0.03	0.84	0.89	1.67	12005600	Jeff R	3:30P	5406
27	Thurs	7.8	0.02	0.82	0.86	1.55	12009800	Jeff R	2:30P	4200
28	Fri	7.9	0.03	0.54	0.60	1.28	12010000	Jeff R	2:30P	200
29	Sat									
30	Sun									
31	Mon	8.0	0.02	0.51	0.57	1.31	12011500	Jeff R	3:30P	1500



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

17 August 2020

Moniteau School District
Attn: Jeffrey Campbell
1810 West Sunbury Road
West Sunbury, PA 16061

Work Order: 0080616
Project: Drinking Water Dassa McKinney - Monthly 802
Project Description: Drinking Water

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
802 Room 617 Sink	0080616-01	Drinking Water	08/06/2020 12:17	8/6/20 15:00	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

Environmental Service Laboratories, Inc., Indiana, PA/TNI Certification #32-00382

Approved By

Rebecca Erwin
Project Manager





1803 Philadelphia Street
 Indiana, PA 15701
 P: (724) 463-8378
 F: (724) 465-4209
 PADEP: 32-00382

1276 Bentleyville Road
 Van Voorhis, PA 15366
 P: (724) 258-8378
 F: (724) 258-8376
 PADEP: 63-04247

435 Broad Street
 Montoursville, PA 17754
 P: (570) 321-9002
 F: (570) 321-1957
 PADEP: 41-04880

950 West Main Street
 Sharpsville, PA 16150
 P: (724) 463-8378 x 500
 F: (724) 465-4209
 PADEP: 43-04934

Moniteau School District
 1810 West Sunbury Road
 West Sunbury, PA 16061

Reported: 08/17/2020 09:12

Lab Sample ID#: 0080616-01
Sample Type: Drinking Water
Sample Source: Grab
Sampler: Paul Somogyi
Client Sample ID: 802 Room 617 Sink

Sample Date: 08/06/2020 12:17
Receipt Date: 08/06/2020 15:00

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/Certification	Prep Date/Time	Analysis Date/Time
Field Analysis		Analytical Method: SM4500-Cl G-11			Prep Method: No Prep - Field		
Chlorine, Free	0.630	mg/L		0.200	PFS	08/06/20 12:17	08/06/20 12:17
Microbiology		Analytical Method: SM9223 B-04			Prep Method: No Prep - Micro		
Total Coliform	Absent	per 100 mL		1	DAA	08/06/20 16:06	08/07/20 17:51
E. Coli	Absent	per 100 mL		1	DAA	08/06/20 16:06	08/07/20 17:51

This sample MEETS current EPA and DEP bacteriological standards of no detectable coliform bacteria per 100 mL sample.

ENVIRONMENTAL SERVICE LABORATORIES, INC.

HEADQUARTER
1803 Philadelphia St.
Indiana, PA 15701
(724) 463-TEST
FAX: (724) 465-4209

SOUTHERN DIVISION
1276 Bentleyville Road
Van Voorhis, PA 15366
(724) 258-TEST
FAX: (724) 258-8376

NORTHERN DIVISION
435 Broad St.
Montoursville, PA
(570) 321-9003
FAX: (570) 321-463-TEST

FOR INTERNAL LABORATORY USE ONLY

SAMPLE REQUEST & STUDY

3E 1 OF 1

Sample Identification	ESL#	Matrix	# of Bottles	Container Type Preservative	Analysis Requested
	801 KITCHEN SINK 802 ROOM 617 SINK	0080616			

Sample Type	Date	Time

THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.

1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1.12% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.)
 2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

Rotation:
 801: Jan, Mar, May, Jul, Sep, Nov
 802: Feb, Apr, Jun, Aug, Oct, Dec

Notes/Special Instructions:
 Drinking Water Dassa McKinney - Monthly

Company/Name: MONITEAU SCHOOL DISTRICT
 Address: 391 HOOKER ROAD
 WEST SUNBURY, PA 16061
 Contact Person: JEFFREY CAMPBELL
 Phone Number: 724-406-4426
 Cell Phone: jcampbell@moniteau.k12.pa.us
 Billing Address:
 PWSID: 5100316

Received By: (Signature) [Signature] Date/ Time 8/10/02 15:00
 Relinquished By: (Signature) [Signature] Date/ Time 8/10/02 14:45

Received By: (Signature) _____ Date/ Time _____
 Relinquished By: (Signature) _____ Date/ Time _____
 Relinquished By: (Signature) _____ Date/ Time _____
 Correct Preservations Y / N / NA Correct Containers Y / N / NA Receipt Temperature 3.0 FH



E-Government Application for Drinking Water Program

SAFE DRINKING WATER ACT

VIEW/EDIT RECORDS

5100316: DASSA MCKINNEY ELEM SCHOOL

SDWA1

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100316	1013	FREE CHLORINE	301	0.63	080620	802		080620	D	1217	32382	0080616-01	BROWNKA_74
5100316	3100	TOTAL COLIFORM PRESENCE	331	0.0	080720	802		080620	D	1217	32382	0080616-01	BROWNKA_75

5100316: DASSA MCKINNEY ELEM SCHOOL

SDWA4

PWSID	Contam ID	Contam	Analysis Method	Result	Lower Limit of Detection	Counting Error	Analysis Date	Loc/EP ID	Loc/EP ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100316	1040	NITRATE	120	0.0	0.10000		080820	101		080620	E	1225	32382	0080597-01	BROWNKA_259
5100316	1041	NITRITE	120	0.0	0.10000		080820	101		080620	E	1225	32382	0080597-01	BROWNKA_260



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

13 August 2020

Moniteau School District
Attn: Jeffrey Campbell
1810 West Sunbury Road
West Sunbury, PA 16061

Work Order: 0081233
Project: Drinking Water Dassa McKinney - Weekly
Project Description: Drinking Water

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
802 Room 617 Sink	0081233-01	Drinking Water	08/13/2020 11:47	8/13/20 14:19	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

Approved By

Rebecca Erwin
Project Manager



1803 Philadelphia Street
 Indiana, PA 15701
 P: (724) 463-8378
 F: (724) 465-4209
 PADEP: 32-00382

1276 Bentleyville Road
 Van Voorhis, PA 15366
 P: (724) 258-8378
 F: (724) 258-8376
 PADEP: 63-04247

435 Broad Street
 Montoursville, PA 17754
 P: (570) 321-9002
 F: (570) 321-1957
 PADEP: 41-04880

950 West Main Street
 Sharpsville, PA 16150
 P: (724) 463-8378 x 500
 F: (724) 465-4209
 PADEP: 43-04934

Moniteau School District
 1810 West Sunbury Road
 West Sunbury, PA 16061

Reported: 08/13/2020 17:21

Lab Sample ID#: 0081233-01
Sample Type: Drinking Water
Sample Source: Grab
Sampler: Paul Somogyi
Client Sample ID: 802 Room 617 Sink

Sample Date: 08/13/2020 11:47
Receipt Date: 08/13/2020 14:19

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
Field Analysis		Analytical Method: SM4500-Cl G-11			Prep Method: No Prep - Field		
Chlorine, Free	0.790	mg/L		0.200	PFS	08/13/20 11:47	08/13/20 11:47

ENVIRONMENTAL SERVICE LABORATORIES, INC.

HEADQUARTER
1803 Philadelphia St.
Indiana, PA 15701
(724) 463-TEST
FAX: (724) 465-4209

SOUTHERN DIVISION
1276 Bentleyville Road
Van Vornhis, PA 15366
(724) 258-TEST
FAX: (724) 258-8376

NORTHE
435 Broc
Montour:
(570) 32.
FAX: (570) 321-1957



0081233

FAX: (724) 465-4209

FOR INTERNAL LABORATORY USE ONLY

SAMPLE REQUEST & CHAIN OF CUSTODY

3E 1 OF 1

Sample Identification	ESL#	Sample Type		Matrix	# of Bottles	Container Type Preservative	Analysis Requested
		Date	Grab Time				
Distribution: <u>802</u>	<u>0081233</u>	<u>8/13/06</u>	<u>11:17</u>	DW	Field	Field	Free Chlorine <u>.79</u> mg/L
<p style="text-align: center;">ROTATION</p> <p>Wk 1 - 801-Kitchen-Sink</p> <p>Wk 2 - 802 Room 617 Sink</p> <p>Wk 3 - 803 Room 606 Sink</p> <p>Wk 4 - 804 Room 408 Sink</p> <p>Wk 5 - 802 Room 617 Sink</p>							
<p>THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.</p> <p>1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.)</p> <p>2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.</p>							
<p>Sampled By: (Signature) <u>[Signature]</u> Date/ Time <u>8/13/06 11:17</u></p> <p>Relinquished By: (Signature) <u>[Signature]</u> Date/ Time <u>8/13/06 13:45</u></p> <p>Relinquished By: (Signature) _____ Date/ Time _____</p> <p>Relinquished By: (Signature) _____ Date/ Time _____</p>				<p>Notes/Special Instructions:</p> <p>Drinking Water Dassa McKinney - Weekly</p>			
<p>Correct Preservations Y/N <u>(NA)</u> Correct Containers Y/N <u>(NA)</u> Receipt Temperature <u>✓</u></p>				<p>Company/Name: MONITEAU SCHOOL DISTRICT</p> <p>Address: 391 HOOKER ROAD WEST SUNBURY, PA 16061 JEFFREY CAMPBELL</p> <p>Contact Person: _____ Phone Number: 724-406-4426</p> <p>Cell Phone: jcampbell@moniteau.k12.pa.us</p> <p>Billing Address: _____ PWSID: 5100316</p>			



E-Government Application for Drinking Water Program

SAFE DRINKING WATER ACT

VIEW/EDIT RECORDS

5100316: DASSA MCKINNEY ELEM SCHOOL

SDWA1

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100316	1013	FREE CHLORINE	301	0.63	080620	802		080620	D	1217	32382	0080616-01	BROWNKA_74
5100316	1013	FREE CHLORINE	301	0.79	081320	802		081320	D	1147	32382	0081233-01	BROWNKA_626
5100316	3100	TOTAL COLIFORM PRESENCE	331	0.0	080720	802		080620	D	1217	32382	0080616-01	BROWNKA_75

5100316: DASSA MCKINNEY ELEM SCHOOL

SDWA4

PWSID	Contam ID	Contam	Analysis Method	Result	Lower Limit of Detection	Counting Error	Analysis Date	Loc/EP ID	Loc/EP ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100316	1040	NITRATE	120	0.0	0.10000		080820	101		080620	E	1225	32382	0080597-01	BROWNKA_259
5100316	1041	NITRITE	120	0.0	0.10000		080820	101		080620	E	1225	32382	0080597-01	BROWNKA_260



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpshville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

20 August 2020

Moniteau School District
Attn: Jeffrey Campbell
1810 West Sunbury Road
West Sunbury, PA 16061

Work Order: 0081880
Project: Drinking Water Dassa McKinney - Weekly
Project Description: Drinking Water

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
801 Kitchen Sink	0081880-01	Drinking Water	08/20/2020 11:35	8/20/20 14:31	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

Approved By

Rebecca Erwin
Project Manager



1803 Philadelphia Street
 Indiana, PA 15701
 P: (724) 463-8378
 F: (724) 465-4209
 PADEP: 32-00382

1276 Bentleyville Road
 Van Voorhis, PA 15366
 P: (724) 258-8378
 F: (724) 258-8376
 PADEP: 63-04247

435 Broad Street
 Montoursville, PA 17754
 P: (570) 321-9002
 F: (570) 321-1957
 PADEP: 41-04880

950 West Main Street
 Sharpville, PA 16150
 P: (724) 463-8378 x 500
 F: (724) 465-4209
 PADEP: 43-04934

Moniteau School District
 1810 West Sunbury Road
 West Sunbury, PA 16061

Reported: 08/20/2020 16:56

Lab Sample ID#: 0081880-01
Sample Type: Drinking Water
Sample Source: Grab
Sampler: Justin Matava
Client Sample ID: 801 Kitchen Sink

Sample Date: 08/20/2020 11:35
Receipt Date: 08/20/2020 14:31

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/Certification	Prep Date/Time	Analysis Date/Time
Field Analysis	Analytical Method: SM4500-Cl G-11				Prep Method: No Prep - Field		
Chlorine, Free	0.480	mg/L		0.200	JDM	08/20/20 11:35	08/20/20 11:35

5100316: DASSA MCKINNEY ELEM SCHOOL
SDWA1

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100316	2450	MONOCHLOROACETIC ACID	206	0.00218	081220	703		081020	D	0815	32382	0080842-01	BROWNKA_1066
5100316	2451	DICHLOROACETIC ACID	206	0.00664	081220	703		081020	D	0815	32382	0080842-01	BROWNKA_1068
5100316	2452	TRICHLOROACETIC ACID	206	0.00172	081220	703		081020	D	0815	32382	0080842-01	BROWNKA_1071
5100316	2453	MONOBROMOACETIC ACID	206	0.0	081220	703		081020	D	0815	32382	0080842-01	BROWNKA_1072
5100316	2454	DIBROMOACETIC ACID	206	0.0	081220	703		081020	D	0815	32382	0080842-01	BROWNKA_1074
5100316	2456	HALOACETIC ACIDS (FIVE)	206	0.0105	081220	703		081020	D	0815	32382	0080842-01	BROWNKA_1076
5100316	2941	CHLOROFORM (THM)	221	0.0206	081420	703		081020	D	0815	32382	0080842-01	BROWNKA_1078
5100316	2942	BROMOFORM (THM)	221	0.0	081420	703		081020	D	0815	32382	0080842-01	BROWNKA_1080
5100316	2943	BROMODICHLOROMETHANE (THM)	221	0.0105	081420	703		081020	D	0815	32382	0080842-01	BROWNKA_1082
5100316	2944	CHLORODIBROMOMETHANE (THM)	221	0.0037	081420	703		081020	D	0815	32382	0080842-01	BROWNKA_1084
5100316	2950	TRICHLOROMETHANES	221	0.0349	081420	703		081020	D	0815	32382	0080842-01	BROWNKA_1086
5100316	2450	MONOCHLOROACETIC ACID	206	0.00237	081720	704		081020	D	0800	32382	0080842-02	BROWNKA_1067
5100316	2451	DICHLOROACETIC ACID	206	0.00806	081720	704		081020	D	0800	32382	0080842-02	BROWNKA_1069
5100316	2452	TRICHLOROACETIC ACID	206	0.00157	081720	704		081020	D	0800	32382	0080842-02	BROWNKA_1070
5100316	2453	MONOBROMOACETIC ACID	206	0.0	081720	704		081020	D	0800	32382	0080842-02	BROWNKA_1073
5100316	2454	DIBROMOACETIC ACID	206	0.0	081720	704		081020	D	0800	32382	0080842-02	BROWNKA_1075
5100316	2456	HALOACETIC ACIDS (FIVE)	206	0.012	081720	704		081020	D	0800	32382	0080842-02	BROWNKA_1077
5100316	2941	CHLOROFORM (THM)	221	0.0264	081420	704		081020	D	0800	32382	0080842-02	BROWNKA_1079
5100316	2942	BROMOFORM (THM)	221	0.0	081420	704		081020	D	0800	32382	0080842-02	BROWNKA_1081

5100316: DASSA MCKINNEY ELEM SCHOOL
SDWA1

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100316	2944	CHLORODIBROMOMETHANE (THM)	221	0.00389	081420	704		081020	D	0800	32382	0080842-02	BROWNKA_1085
5100316	2950	TRihalOMETHANES	221	0.0413	081420	704		081020	D	0800	32382	0080842-02	BROWNKA_1087
5100316	1013	FREE CHLORINE	301	0.48	082020	801		082020	D	1135	32382	0081880-01	BROWNKA_1408
5100316	1013	FREE CHLORINE	301	0.63	080620	802		080620	D	1217	32382	0080616-01	BROWNKA_74
5100316	1013	FREE CHLORINE	301	0.79	081320	802		081320	D	1147	32382	0081233-01	BROWNKA_626
5100316	3100	TOTAL COLIFORM PRESENCE	331	0.0	080720	802		080620	D	1217	32382	0080616-01	BROWNKA_75

5100316: DASSA MCKINNEY ELEM SCHOOL
SDWA4

PWSID	Contam ID	Contam	Analysis Method	Result	Lower Limit of Detection	Counting Error	Analysis Date	Loc/EP ID	Loc/EP ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100316	1040	NITRATE	120	0.0	0.10000		080820	101		080620	E	1225	32382	0080597-01	BROWNKA_259
5100316	1041	NITRITE	120	0.0	0.10000		080820	101		080620	E	1225	32382	0080597-01	BROWNKA_260
5100316	2378	1,2,4-TRICHLOROBENZE	221	0.0	0.00050		081220	101		080620	E	1225	32382	0080598-01	BROWNKA_691
5100316	2380	cis-1,2-DICHLOROETHYLENE	221	0.0	0.00050		081220	101		080620	E	1225	32382	0080598-01	BROWNKA_693
5100316	2955	XYLENES (TOTAL)	221	0.0	0.00050		081220	101		080620	E	1225	32382	0080598-01	BROWNKA_695
5100316	2964	DICHLOROMETHANE	221	0.0	0.00050		081220	101		080620	E	1225	32382	0080598-01	BROWNKA_697
5100316	2968	o-DICHLOROBENZENE	221	0.0	0.00050		081220	101		080620	E	1225	32382	0080598-01	BROWNKA_699
5100316	2969	PARA-DICHLOROBENZENE	221	0.0	0.00050		081220	101		080620	E	1225	32382	0080598-01	BROWNKA_701
5100316	2976	VINYL CHLORIDE	221	0.0	0.00050		081220	101		080620	E	1225	32382	0080598-01	BROWNKA_703
5100316	2977	1,1-DICHLOROETHYLENE	221	0.0	0.00050		081220	101		080620	E	1225	32382	0080598-01	BROWNKA_705



E-Government Application for Drinking Water Program
 SAFE DRINKING WATER ACT
 VIEW/EDIT RECORDS

5100316: DASSA MCKINNEY ELEM SCHOOL
SDWA4

PWSID	Contam ID	Contam	Analysis Method	Result	Lower Limit of Detection	Counting Error	Analysis Date	Loc/EP ID	Loc/EP ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100316	2979	trans-1,2-DICHLOROETHYLENE	221	0.0	0.00050		081220	101		080620	E	1225	32382	0080598-01	BROWNKA 707
5100316	2980	1,2-DICHLOROETHANE	221	0.0	0.00050		081220	101		080620	E	1225	32382	0080598-01	BROWNKA 709
5100316	2981	1,1,1-TRICHLOROETHANE	221	0.0	0.00050		081220	101		080620	E	1225	32382	0080598-01	BROWNKA 711
5100316	2982	CARBON TETRACHLORIDE	221	0.0	0.00050		081220	101		080620	E	1225	32382	0080598-01	BROWNKA 713
5100316	2983	1,2-DICHLOROPROPANE	221	0.0	0.00050		081220	101		080620	E	1225	32382	0080598-01	BROWNKA 715
5100316	2984	TRICHLOROETHYLENE	221	0.0	0.00050		081220	101		080620	E	1225	32382	0080598-01	BROWNKA 717
5100316	2985	1,1,2-TRICHLOROETHANE	221	0.0	0.00050		081220	101		080620	E	1225	32382	0080598-01	BROWNKA 719
5100316	2987	TETRACHLOROETHYLENE	221	0.0	0.00050		081220	101		080620	E	1225	32382	0080598-01	BROWNKA 721
5100316	2989	CHLOROBENZENE	221	0.0	0.00050		081220	101		080620	E	1225	32382	0080598-01	BROWNKA 723
5100316	2990	BENZENE	221	0.0	0.00050		081220	101		080620	E	1225	32382	0080598-01	BROWNKA 725
5100316	2991	TOLUENE	221	0.0	0.00050		081220	101		080620	E	1225	32382	0080598-01	BROWNKA 727
5100316	2992	ETHYLBENZENE	221	0.0	0.00050		081220	101		080620	E	1225	32382	0080598-01	BROWNKA 729
5100316	2996	STYRENE	221	0.0	0.00050		081220	101		080620	E	1225	32382	0080598-01	BROWNKA 731

**ENVIRONMENTAL SERVICE
LABORATORIES, INC.**

HEADQUARTER
1803 Philadelphia St.
Indiana, PA 15701
(724) 463-TEST
FAX: (724) 465-4209

SOUTHERN DIVISION
1276 Bentleyville Road
Van Voorhis, PA 15366
(724) 258-TEST
FAX: (724) 258-8376

0081880
(570) 321-9003
FAX: (570) 321-1957

FOR INTERNAL LABORATORY USE ONLY

CHAIN OF CUSTODY

NORTHWEST DIVISION
Main Street
Sharpville, PA 16
(724) 463-TEST
FAX: (724) 465-4209

Sample Identification	ESL#	Sample Type		Matrix	# of Bottles	Container Type	Analysis Requested
		Grab	Time				
Distribution: 801	0081880		1135	DW	Field	Field	Free Chlorine 0.48 mg/L
<p>ROTATION</p> <p>Wk 1 - 801 Kitchen Sink</p> <p>Wk 2 - 802 Room 617 Sink</p> <p>Wk 3 - 803 Room 606 Sink</p> <p>Wk 4 - 804 Room 408 Sink</p> <p>Wk 5 - 802 Room 617 Sink</p>							
<p>THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.</p> <p>1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (18% PER ANNUM) OR THE MAXIMUM ALLOWED BY LAW.</p> <p>2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.</p>							
<p>Sampled By: (Signature) <i>[Signature]</i> Date/ Time 8/20/10 1135</p> <p>Relinquished By: (Signature) <i>[Signature]</i> Date/ Time 8/20/10 1430</p> <p>Relinquished By: (Signature) _____ Date/ Time _____</p> <p>Relinquished By: (Signature) _____ Date/ Time _____</p> <p>Relinquished By: (Signature) _____ Date/ Time _____</p>				<p>Received By: (Signature) <i>[Signature]</i> Date/ Time 8/20/10 14:30</p> <p>Received By: (Signature) _____ Date/ Time _____</p> <p>Received By: (Signature) _____ Date/ Time _____</p>			
<p>Correct Preservations Y / N (NA)</p>				<p>Correct Containers Y / N (NA)</p>			
<p>Receipt Temperature _____</p>				<p>Company Name: MONITEAU SCHOOL DISTRICT</p> <p>Address: 391 HOOKER ROAD WEST SUNBURY, PA 16061 JEFFREY CAMPBELL 724-406-4426 jcampbell@moniteau.k12.pa.us 5100316</p>			
<p>Notes/Special Instructions: Drinking Water Dassa McKinney - Weekly</p>							



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

28 August 2020

Moniteau School District
Attn: Jeffrey Campbell
1810 West Sunbury Road
West Sunbury, PA 16061

Work Order: 0082418
Project: Drinking Water Dassa McKinney - Weekly
Project Description: Drinking Water

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
804 400 Hall RR Sink	0082418-01	Drinking Water	08/27/2020 11:05	8/27/20 14:37	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

Approved By

Rebecca Erwin
Project Manager



1803 Philadelphia Street
 Indiana, PA 15701
 P: (724) 463-8378
 F: (724) 465-4209
 PADEP: 32-00382

1276 Bentleyville Road
 Van Voorhis, PA 15366
 P: (724) 258-8378
 F: (724) 258-8376
 PADEP: 63-04247

435 Broad Street
 Montoursville, PA 17754
 P: (570) 321-9002
 F: (570) 321-1957
 PADEP: 41-04880

950 West Main Street
 Sharpsville, PA 16150
 P: (724) 463-8378 x 500
 F: (724) 465-4209
 PADEP: 43-04934

Moniteau School District
 1810 West Sunbury Road
 West Sunbury, PA 16061

Reported: 08/28/2020 11:54

Lab Sample ID#: 0082418-01
Sample Type: Drinking Water
Sample Source: Grab
Sampler: Paul Somogyi
Client Sample ID: 804 400 Hall RR Sink

Sample Date: 08/27/2020 11:05
Receipt Date: 08/27/2020 14:37

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/Certification	Prep Date/Time	Analysis Date/Time
Field Analysis	Analytical Method: SM4500-Cl G-11		Prep Method: No Prep - Field				
Chlorine, Free	0.820	mg/L		0.200	PFS	08/27/20 11:05	08/27/20 11:05

ENVIRONMENTAL SERVICE LABORATORIES, INC.

HEADQUARTER
1803 Philadelphia St.
Indiana, PA 15701
(724) 463-TEST
FAX: (724) 465-4209

SOUTHERN DIVISION
1276 Bentleyville Road
Van Voorhis, PA 15366
(724) 258-TEST
FAX: (724) 258-8376

NO. 43
Mk
(5)



0082418

DIVISION

31

16

(724) 463-TEST
FAX: (724) 465-4209

FOR INTERNAL LABORATORY USE ONLY

Sample Identification	ESL#	Sample Type		Matrix	# of Bottles	Container Type	Analysis Requested
		Grab	Time				
Distribution: <u>804</u>	<u>0082418</u>	Date: <u>8/27/20</u>	Time: <u>1105</u>	DW	Field	Field	Free Chlorine <u>.82</u> mg/L
<p>ROTATION</p> <p>Wk 1 - 801 Kitchen Sink</p> <p>Wk 2 - 802 Room 617 Sink</p> <p>Wk 3 - 803 Room 606 Sink</p> <p><u>Wk 4 - 804 Room 408 Sink</u></p> <p>Wk 5 - 802 Room 617 Sink</p>							

Notes/Special Instructions:

Drinking Water Dassa McKinney - Weekly

- THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW).
- THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

Sampled By: (Signature) [Signature] Date/ Time 8-27-20 1105

Relinquished By: (Signature) [Signature] Date/ Time 8-27-20 1320

Relinquished By: (Signature) _____ Date/ Time _____

Relinquished By: (Signature) _____ Date/ Time _____

Correct Preservations Y / N (NA) Correct Containers Y / N (NA) Receipt Temperature _____

Company/Name: **MONITEAU SCHOOL DISTRICT**

Address: **391 HOOKER ROAD
WEST SUNBURY, PA 16061
JEFFREY CAMPBELL**

Contact Person: _____

Phone Number: **724-406-4426**

Cell Phone: _____

Email Address: **jcampbell@moniteau.k12.pa.us**

Billing Address: _____

PWSID: **5100316**

5100316: DASSA MCKINNEY ELEM SCHOOL
SDWA1

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100316	2450	MONOCHLOROACETIC ACID	206	0.00218	081220	703		081020	D	0815	32382	0080842-01	BROWNKA_1066
5100316	2451	DICHLOROACETIC ACID	206	0.00664	081220	703		081020	D	0815	32382	0080842-01	BROWNKA_1068
5100316	2452	TRICHLOROACETIC ACID	206	0.00172	081220	703		081020	D	0815	32382	0080842-01	BROWNKA_1071
5100316	2453	MONOBROMOACETIC ACID	206	0.0	081220	703		081020	D	0815	32382	0080842-01	BROWNKA_1072
5100316	2454	DIBROMOACETIC ACID	206	0.0	081220	703		081020	D	0815	32382	0080842-01	BROWNKA_1074
5100316	2456	HALOACETIC ACIDS (FIVE)	206	0.0105	081220	703		081020	D	0815	32382	0080842-01	BROWNKA_1076
5100316	2941	CHLOROFORM (THM)	221	0.0206	081420	703		081020	D	0815	32382	0080842-01	BROWNKA_1078
5100316	2942	BROMOFORM (THM)	221	0.0	081420	703		081020	D	0815	32382	0080842-01	BROWNKA_1080
5100316	2943	BROMODICHLOROMETHANE (THM)	221	0.0105	081420	703		081020	D	0815	32382	0080842-01	BROWNKA_1082
5100316	2944	CHLORODIBROMOMETHANE (THM)	221	0.0037	081420	703		081020	D	0815	32382	0080842-01	BROWNKA_1084
5100316	2950	TRIHALOMETHANES	221	0.0349	081420	703		081020	D	0815	32382	0080842-01	BROWNKA_1086
5100316	2450	MONOCHLOROACETIC ACID	206	0.00237	081720	704		081020	D	0800	32382	0080842-02	BROWNKA_1067
5100316	2451	DICHLOROACETIC ACID	206	0.00806	081720	704		081020	D	0800	32382	0080842-02	BROWNKA_1069
5100316	2452	TRICHLOROACETIC ACID	206	0.00157	081720	704		081020	D	0800	32382	0080842-02	BROWNKA_1070
5100316	2453	MONOBROMOACETIC ACID	206	0.0	081720	704		081020	D	0800	32382	0080842-02	BROWNKA_1073
5100316	2454	DIBROMOACETIC ACID	206	0.0	081720	704		081020	D	0800	32382	0080842-02	BROWNKA_1075
5100316	2456	HALOACETIC ACIDS (FIVE)	206	0.012	081720	704		081020	D	0800	32382	0080842-02	BROWNKA_1077
5100316	2941	CHLOROFORM (THM)	221	0.0264	081420	704		081020	D	0800	32382	0080842-02	BROWNKA_1079
5100316	2942	BROMOFORM (THM)	221	0.0	081420	704		081020	D	0800	32382	0080842-02	BROWNKA_1081

5100316: DASSA MCKINNEY ELEM SCHOOL

SDWA1

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100316	2944	CHLORODIBROMOMETHANE (THM)	221	0.00389	081420	704		081020	D	0800	32382	0080842-02	BROWNKA_1085
5100316	2950	TRIHALOMETHANES	221	0.0413	081420	704		081020	D	0800	32382	0080842-02	BROWNKA_1087
5100316	1013	FREE CHLORINE	301	0.48	082020	801		082020	D	1135	32382	0081880-01	BROWNKA_1408
5100316	1013	FREE CHLORINE	301	0.63	080620	802		080620	D	1217	32382	0080616-01	BROWNKA_74
5100316	1013	FREE CHLORINE	301	0.79	081320	802		081320	D	1147	32382	0081233-01	BROWNKA_626
5100316	3100	TOTAL COLIFORM PRESENCE	331	0.0	080720	802		080620	D	1217	32382	0080616-01	BROWNKA_75
5100316	1013	FREE CHLORINE	301	0.82	082720	804		082720	D	1105	32382	0082418-01	BROWNKA_1933

5100316: DASSA MCKINNEY ELEM SCHOOL

SDWA4

PWSID	Contam ID	Contam	Analysis Method	Result	Lower Limit of Detection	Counting Error	Analysis Date	Loc/EP ID	Loc/EP ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100316	1040	NITRATE	120	0.0	0.10000		080820	101		080620	E	1225	32382	0080597-01	BROWNKA_259
5100316	1041	NITRITE	120	0.0	0.10000		080820	101		080620	E	1225	32382	0080597-01	BROWNKA_260
5100316	2378	1,2,4-TRICHLOROBENZE	221	0.0	0.00050		081220	101		080620	E	1225	32382	0080598-01	BROWNKA_691
5100316	2380	cis-1,2-DICHLOROETHYLENE	221	0.0	0.00050		081220	101		080620	E	1225	32382	0080598-01	BROWNKA_693
5100316	2955	XYLENES (TOTAL)	221	0.0	0.00050		081220	101		080620	E	1225	32382	0080598-01	BROWNKA_695
5100316	2964	DICHLOROMETHANE	221	0.0	0.00050		081220	101		080620	E	1225	32382	0080598-01	BROWNKA_697
5100316	2968	o-DICHLOROBENZENE	221	0.0	0.00050		081220	101		080620	E	1225	32382	0080598-01	BROWNKA_699
5100316	2969	PARA-DICHLOROBENZENE	221	0.0	0.00050		081220	101		080620	E	1225	32382	0080598-01	BROWNKA_701
5100316	2976	VINYL CHLORIDE	221	0.0	0.00050		081220	101		080620	E	1225	32382	0080598-01	BROWNKA_703

**5100316: DASSA MCKINNEY ELEM SCHOOL
SDWA4**

PWSID	Contam ID	Contam	Analysis Method	Result	Lower Limit of Detection	Counting Error	Analysis Date	Loc/EP ID	Loc/EP ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100316	2977	1,1-DICHLOROETHYLENE	221	0.0	0.00050		081220	101		080620	E	1225	32382	0080598-01	BROWNKA 705
5100316	2979	trans-1,2-DICHLOROETHYLENE	221	0.0	0.00050		081220	101		080620	E	1225	32382	0080598-01	BROWNKA 707
5100316	2980	1,2-DICHLOROETHANE	221	0.0	0.00050		081220	101		080620	E	1225	32382	0080598-01	BROWNKA 709
5100316	2981	1,1,1-TRICHLOROETHANE	221	0.0	0.00050		081220	101		080620	E	1225	32382	0080598-01	BROWNKA 711
5100316	2982	CARBON TETRACHLORIDE	221	0.0	0.00050		081220	101		080620	E	1225	32382	0080598-01	BROWNKA 713
5100316	2983	1,2-DICHLOROPROPANE	221	0.0	0.00050		081220	101		080620	E	1225	32382	0080598-01	BROWNKA 715
5100316	2984	TRICHLOROETHYLENE	221	0.0	0.00050		081220	101		080620	E	1225	32382	0080598-01	BROWNKA 717
5100316	2985	1,1,2-TRICHLOROETHANE	221	0.0	0.00050		081220	101		080620	E	1225	32382	0080598-01	BROWNKA 719
5100316	2987	TETRACHLOROETHYLENE	221	0.0	0.00050		081220	101		080620	E	1225	32382	0080598-01	BROWNKA 721
5100316	2989	CHLOROBENZENE	221	0.0	0.00050		081220	101		080620	E	1225	32382	0080598-01	BROWNKA 723
5100316	2990	BENZENE	221	0.0	0.00050		081220	101		080620	E	1225	32382	0080598-01	BROWNKA 725
5100316	2991	TOLUENE	221	0.0	0.00050		081220	101		080620	E	1225	32382	0080598-01	BROWNKA 727
5100316	2992	ETHYLBENZENE	221	0.0	0.00050		081220	101		080620	E	1225	32382	0080598-01	BROWNKA 729
5100316	2996	STYRENE	221	0.0	0.00050		081220	101		080620	E	1225	32382	0080598-01	BROWNKA 731

**Moniteau School District
Maintenance Department
Moniteau High School
Wastewater Treatment Plant
Monthly Operations Report for
August 2020**

Moniteau High School Sewage Treatment Plant				Daily Operations Worksheet			
Permit # PA0091341							
Date	Day	#1 PH	#1 DO	#2 PH	#2 DO	Month	Operator
8/3	Mon	6.56	7.58	Sht	Down	August	JEFF C
8/4	Tues	6.62	7.61	"	"	5.0	JEFF C
8/5	Wed.	6.71	7.64	"	"	4.8	JEFF C
8/6	Thurs	6.75	7.65	"	"	5.0	JEFF C
8/7	Fri	6.80	8.47	"	"	5.3	JEFF C
8/9	Sun	6.99	9.58	"	"	5.3	JEFF C
8/10	Mon	7.04	9.62	"	"	5.3	JEFF C
8/11	Tues	7.05	9.65	"	"	5.2	JEFF C
8/12	Wed	7.12	9.24	"	"	5.1	JEFF C
8/13	Thurs	7.12	9.26	"	"	5.1	JEFF C
8/14	Fri	7.15	9.31	"	"	5.0	JEFF C
8/17	Mon	7.17	9.33	"	"	5.1	JEFF C
8/18	Tues	7.21	9.30	"	"	5.1	JEFF C
8/19	Wed	7.21	9.31	"	"	5.1	JEFF C
8/20	Thurs	7.28	9.28	"	"	5.1	JEFF C
8/21	Fri	7.13	9.35	"	"	5.1	JEFF C
8/24	Mon	7.00	9.17	"	"	4.5	JEFF C
8/25	Tues	6.89	9.03	"	"	4.5	JEFF C
8/26	Wed	6.91	9.05	"	"	4.5	JEFF C
8/27	Thurs	6.91	9.03	"	"	4.3	JEFF C
8/28	Fri	6.90	9.01	"	"	4.3	JEFF C
8/31	Mon	6.88	7.00	"	"	4.0	JEFF C
					108 ÷ 24	3,725,182	
						63,983 ÷ 31	
						2,063.97	Daily

DISCHARGE MONITORING REPORT (DMR)

NAME: MONITEAU SCH DIST
 ADDRESS: 1810 W SUNBURY RD, WEST SUNBURY, PA , 16061-1220
 FACILITY: MONITEAU JR SR HIGH SCHOOL
 LOCATION: 1810 W SUNBURY RD, WEST SUNBURY, PA , 16061-1220
 STAGE: Final Effluent

Reporting Frequency: Monthly
 DMR Effective From: 08/01/2020
 DMR Effective To: 08/31/2020
 Permit Expires: 05/31/2022
 Permit Application Due: 12/02/2021
 No Discharge:

PA0091341	001
PERMIT NUMBER	OUTFALL NUMBER

MONITORING PERIOD			
YEAR	MO	DAY	TO
2020	08	01	31

FROM

PARAMETER	SAMPLE MEASUREMENT	QUANTITY OR LOADING		QUANTITY OR CONCENTRATION				SAMPLING FREQUENCY	SAMPLING TYPE
		VALUE	UNITS	VALUE	VALUE	VALUE	UNITS		
Dissolved Oxygen (00300)	SAMPLE MEASUREMENT	***	***	7.58	***	***	***	1/week	Grab
	PERMIT REQUIREMENT	***	***	4.0 Min	***	***	***	1/week	Grab
pH (00400)	SAMPLE MEASUREMENT	***	***	6.56	***	7.28	S.U.	1/week	Grab
	PERMIT REQUIREMENT	***	***	6.0 Min	***	9.0 Max	***	1/week	Grab
Total Suspended Solids (00530)	SAMPLE MEASUREMENT	***	***	***	<5.0	***	***	2/month	Grab
	PERMIT REQUIREMENT	***	***	***	30 Avg Mo	***	***	2/month	Grab
Total Nitrogen (00600)	SAMPLE MEASUREMENT	***	***	***	15.55	***	***	2/month	Grab
	PERMIT REQUIREMENT	***	***	***	Monitor & Report Avg Mo	***	***	2/month	Grab
Total Phosphorus (00665)	SAMPLE MEASUREMENT	***	***	***	1.40	***	***	2/month	Grab
	PERMIT REQUIREMENT	***	***	***	Monitor & Report Avg Mo	***	***	2/month	Grab
Ultraviolet light intensity (48607)	SAMPLE MEASUREMENT	***	***	***	4.91	***	***	1/week	Grab
	PERMIT REQUIREMENT	***	***	***	Monitor & Report Avg Mo	***	***	1/week	Grab
Flow (50050)	SAMPLE MEASUREMENT	.002063	MGD	***	***	***	***	1/week	Measured
	PERMIT REQUIREMENT	Monitor & Report Avg Mo	***	***	***	***	***	1/week	Measured

DISCHARGE MONITORING REPORT (DMR)

PARAMETER	SAMPLE MEASUREMENT	QUANTITY OR LOADING			QUANTITY OR CONCENTRATION				SAMPLING FREQUENCY	SAMPLING TYPE
		VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Fecal Coliform (74055)	SAMPLE MEASUREMENT	***		***	<1.0	<1.0			2/month	Grab
	PERMIT REQUIREMENT	***		***	200	1000	IMAX	No./100 ml	2/month	Grab
Carbonaceous Biochemical Oxygen Demand (CBOD5) (80082)	SAMPLE MEASUREMENT	***		***	<3.0	***			2/month	Grab
	PERMIT REQUIREMENT	***		***	25	Avg Mo	***	mg/L	2/month	Grab
Facility Comments										

COMMENT DETAILS

COMMENTS	OPERATOR NAME	OPERATOR CERTIFICATION NUMBER	OPERATOR CONTACT NUMBER
----------	---------------	-------------------------------	-------------------------

Your eDMR Report Has Been Received For Permit No. PA0091341

From: depgreenporthelpdesk@state.pa.us

To: monwarrior2003@yahoo.com; monwarrior2003@yahoo.com; mcafoose92@hotmail.com

Date: Wednesday, September 16, 2020, 08:26 AM EDT

This email is to confirm that the following report was received by DEP through the eDMR system:

Facility Name: MONITEAU JR SR HIGH SCHOOL

Permit Number: PA0091341

Report Frequency: Monthly

Report Type: DMR

Reporting Period: 08/01/2020-08/31/2020

Report Due Date: 09/28/2020

Submitted By: Jeffrey Campbell

Submission Id: 225416

Submission Status: Received

Submission Type: Original

To view the details of this report, access the eDMR system through DEP's [GreenPort](#) and select the link for View/Revise Submitted.

Moniteau High School - Sewage Plant
Monthly Work Sheet
August 2020

Flow $63,983 \div 31 = 2,063.97$ Daily Avg.

UV $108 \div 22 = 4.91$ Avg.

PH Low 6.56

High 7.28

D.O. Low 7.58

High 9.35

Total Nitrogen - $24.6 + 7.05 = 31.11 \div 2 = 15.55$

TSS - $< 5 + < 5 = < 5$

Nitrate / Nitrite - $24.6 + 6.42 = 31.02 \div 2 = 15.51$

Phos. - $1.4 + 1.4 = 2.8 \div 2 = 1.4$

CBOD $< 3.00 + < 3.00 = < 3.00$

FECAL - $< 1 + < 1 = < 1$



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

21 August 2020

Moniteau School District
Attn: Jeffrey Campbell
1810 West Sunbury Road
West Sunbury, PA 16061

Work Order: 0080596
Project: Wastewater
Project Description: Wastewater

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
Effluent Outfall 001	0080596-01	Waste Water	08/06/2020 11:00	8/6/20 15:00	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

TKN subcontracted to Suburban Water Testing Laboratory-Reading, PA DEP Lab ID 06-00208; please see attached subcontract laboratory Report of Analysis for results.

Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

Environmental Service Laboratories, Inc., Indiana, PA/TNI Certification #32-00382

Approved By

Rebecca Erwin
Project Manager





1803 Philadelphia Street
 Indiana, PA 15701
 P: (724) 463-8378
 F: (724) 465-4209
 PADEP: 32-00382

1276 Bentleyville Road
 Van Voorhis, PA 15366
 P: (724) 258-8378
 F: (724) 258-8376
 PADEP: 63-04247

435 Broad Street
 Montoursville, PA 17754
 P: (570) 321-9002
 F: (570) 321-1957
 PADEP: 41-04880

950 West Main Street
 Sharpsville, PA 16150
 P: (724) 463-8378 x 500
 F: (724) 465-4209
 PADEP: 43-04934

Moniteau School District
 1810 West Sunbury Road
 West Sunbury, PA 16061

Reported: 08/21/2020 12:13

Lab Sample ID#: 0080596-01
Sample Type: Waste Water
Sample Source: Grab
Sampler: Client
Client Sample ID: Effluent Outfall 001

Sample Date: 08/06/2020 11:00
Receipt Date: 08/06/2020 15:00

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
General Chemistry	Analytical Method: CALC				Prep Method: [CALC]		
Total Nitrogen	24.6	mg/L		1.04	DAA	08/19/20 09:00	08/19/20 14:16
General Chemistry	Analytical Method: SM2540 D-11				Prep Method: No Prep - WetChem		
Total Suspended Solids	<5	mg/L		5	LMB	08/11/20 13:45	08/11/20 14:45
General Chemistry	Analytical Method: SM4500-NO3 E-11 (discrete)				Prep Method: No Prep - WetChem		
Nitrate/Nitrite	24.6	mg/L		1.04	DAA	08/19/20 09:00	08/19/20 14:16
General Chemistry	Analytical Method: SM4500-P E-11				Prep Method: No Prep - WetChem		
Phosphorus	1.4	mg/L		0.20	JPD	08/20/20 07:39	08/21/20 07:20
General Chemistry	Analytical Method: SM5210 B-11				Prep Method: No Prep - WetChem		
Carbonaceous Biochemical Oxygen Demand	<3.00	mg/L		3.00	JAW	08/07/20 13:10	08/12/20 09:05
Microbiology	Analytical Method: Colilert-18				Prep Method: No Prep - Micro		
Fecal Coliforms	1	MPN/100 mL		1	DAA	08/06/20 15:28	08/07/20 13:03

**ENVIRONMENTAL SERVICE
LABORATORIES, INC.**

HEADQUARTERS
1803 Philadelphia St.
Indiana, PA 15701
(724) 463-TEST
FAX: (724) 465-4209

SOUTHERN DIVISION
1276 Bentleyville Road
Van Vorthis, PA 15366
(724) 258-TEST
FAX: (724) 258-8376

NORTHWEST DIVISION
4351 Main Street
Pittsburgh, PA 15110
(724) 463-TEST
FAX: (724) 465-4209

FOR INTERNAL LABORATORY USE ONLY



SAMPLE REQUEST & CHAIN OF CUSTODY

Sample Identification	ESL#	Sample Type		Date	Grab Time	Matrix	# of Containers	Container Type	Analysis Requested
		Composite	Time on/off						
Effluent Outfall 001	0080596			8/6/20	11:00 AM	WW	1	Poly 1000mL	CBOD, TSS
						WW	1	None	Total Nitrogen, Total Phosphorus
						WW	1	Poly 1000mL H2SO4	Fecal Coliform
								Sterile Plastic 125mL Na2S2O3	

Project Notes:

Wastewater

Company/Name:

MONTEAU SCHOOL DISTRICT

Contact Person:

JEFFREY CAMPBELL

Address:

**1810 WEST SUNBURY ROAD
WEST SUNBURY, PA 16061**

Phone / Cell:

724-406-4426

Email:

jcampbell@monteau.k12.pa.us

1. THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.
2. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1.12% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW).
3. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

Sampled By: (Signature) *[Signature]* Date/ Time 8/6/20 11:00 AM

Relinquished By: (Signature) *[Signature]* Date/ Time 8/6/20 12:50

Received By: (Signature) *[Signature]* Date/ Time 8/6/20 12:50

Relinquished By: (Signature) *[Signature]* Date/ Time 8/6/20 14:15

Received By: (Signature) *[Signature]* Date/ Time 8/6/20 15:00

Relinquished By: (Signature) _____ Date/ Time _____

Received By: (Signature) _____ Date/ Time _____

Correct Preservations Y / N / NA

Correct Containers Y / N / NA

Receipt Temperature



SAMPLE RECEIPT AND REVIEW FORM

PART A: General Information



0080596

Client: <u>Monitew</u>		Work Order: _____	
Received by: <u>JM</u>	Date/Time Received: <u>8/6/20 15:00</u>	Date Sampled: <u>8/6/20</u>	
Method of Delivery: FedEx UPS Client Drop off <u>ESL courier</u> Other: _____			
Sample Receipt Temp: <u>3.0</u>		Samples Received on Ice: <u>YES</u> NO	
IR Gun # Used: 1 2 3 <u>(4)</u>			
Samples Removed by Satellite Lab Division: Southern(BV) NorthWest(NW) Northern(WP)		Containers removed by Satellite Lab for analysis of:	TCMPN Fecal Coliform TC/EC ECMPN
Sample State of Collection: <u>PA</u> NY OH WV Other: _____		PWSID COMPLIANCE DRINKING WATER SAMPLES: YES <u>NO</u>	

PART B: Receipt Details

Completed (if different from above): _____ / _____ / _____
Signature Date Time

Sample Receipt Criteria	Yes	No	N/A	Comments/Qualifiers (Required for Non-Conforming Items)	Deficiency Log Required
1 Chain of custody documents included with samples?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Comments:	YES NO <input checked="" type="checkbox"/>
2 COC form is properly signed in relinquished/received sections?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Comments:	YES NO <input checked="" type="checkbox"/>
3 Sample containers intact and sealed?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Circle Applicable: Damaged container Leaking container Custody Seal Broken Other:	YES NO <input checked="" type="checkbox"/>
4 Number of containers received match number indicated on COC?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Sample ID's affected:	YES NO <input checked="" type="checkbox"/>
5 Sample ID's on COC match ID's on bottles?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Sample ID's and containers affected:	YES NO <input checked="" type="checkbox"/>
6 Date and time on COC match date and time on bottles?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Sample ID's affected:	YES NO <input checked="" type="checkbox"/>
7 Samples received within holding time?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	ID's and tests affected:	YES NO <input checked="" type="checkbox"/>
8 Samples received at appropriate pH for analysis requested?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Sample ID's, containers affected and observed pH:	YES NO <input checked="" type="checkbox"/>
9 Samples requiring thermal preservation within 0 ≤ 6°C? Microbiology within 0 ≤ 10°C?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	For non-WV samples outside of thermal preservation range sampled same day and received on ice are considered acceptable condition as the cooling process has begun.	YES NO <input checked="" type="checkbox"/>
11 Adequate sample volume received?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Analyses Affected:	YES NO <input checked="" type="checkbox"/>
10 VOA vials free of headspace (defined as < 6mm bubble)?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Sample ID's and containers affected:	YES NO <input checked="" type="checkbox"/>
Other Comments:					Deficiency Log Created: Yes <input checked="" type="checkbox"/> No



Results Report

Order ID: 0082597

Environmental Service Laboratories, Inc. 1803 Philadelphia Street Indiana, PA 15701	Project: TKN Testing
Attn: Accounts Payable	Regulatory ID:

Sample Number: 0082597-01	Site: 0080596-01	Sample ID:							
Collector: Client	Collect Date: 08/06/2020 11:00 am	Sample Type: Grab							
Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By

Inorganics										
Total Kjeldahl Nitrogen (TKN)	< 0.50	M2	mg/L	EPA 351.2	0.50	1	08/19/20	ZJH	08/20/20 10:47	DWL

Data Qualifiers:

M2 The Matrix Spike associated with this sample is below established acceptance criteria, indicating potential matrix interference. Results of this sample may be biased low.

Sample Receipt Conditions:

All samples met the sample receipt requirements for the relevant analyses.

The test *pH, Lab* is performed in the Laboratory as soon as possible. These results are not appropriate for compliance with NPDES, SDWA, or other regulatory programs that require analysis within 15 minutes of sample collection and should be considered for informational purposes only.

**pH, Final* for ASTM leachate is performed by method SM 4500-H-B.

All results meet the requirements of STL's TNI (NELAC) Accredited Quality System unless otherwise noted. If your results contain any data qualifiers or comments, you should evaluate useability relative to your needs.

If collectors initials include "STL", samples have been collected in accordance with STL SOP SL0015.

All results reported on an As Received (Wet Weight) basis unless otherwise noted.

This laboratory report may not be reproduced, except in full, without the written approval of STL.

Results are considered Preliminary unless report is signed by authorized representative of STL.

Reviewed and Released By:

Lisa F. Care
Project Manager I

Report Generated On: 08/21/2020 9:58 am 0082597
STL_Results Revision #1.9 Effective: 04/16/2020





0082597
Lisa F. Care

CONTRACT ORDER

Service Laboratories, Inc.

0080596

envlabs.com. Contact ESL with any questions.

SENDING LABORATORY:

Environmental Service Laboratories, Inc.
1803 Philadelphia Street
Indiana, PA 15701
Phone: 724-463-8378
Fax: 724-465-4209
Project Manager: Rebecca Erwin

RECEIVING LABORATORY:

Suburban Water Testing Labs - Reading
1037F MacArthur Road
Reading, PA 19605
Phone: (610) 375-8378
Fax: 1610-375-4090

State of Origin: PA

Analysis	Due	Expires	Comments
Sample ID: 0080596-01			
Matrix: Water	Sampled: 08/06/2020 11:00	Sample Type: Grab	Sampled By: Client
Total Kjeldahl Nitrogen		08/18/2020 23:00	09/03/2020 11:00
Containers Supplied: Poly 250mL, H2SO4 (D)			

(1) 250mL H2SO4 P
PHCZ cmv

Suburban Testing Labs

* Field tech needs to fill out cmv 8/7/20

Lab Date/Time: 8-7-20 1415 Lab Temp: 27°C
 Number of containers/coolers match number on COC? N
 Sample labels and COC are free of discrepancies? N
 All containers in tact? N
 Received in lab within acceptable temperature limits? N
 40mL VOA vials free of headspace? N
 Relinquished by: CMV
 Received in Lab by: CMV 8-7-20 1415
 (1)

Released By: [Signature] Date: 8/6/20
 Received By: [Signature] Date: 8/7/20
 Released By: [Signature] Date: 8/7/20
 Received By: [Signature] Date: 8-7-20 0935





1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

03 September 2020

Moniteau School District
Attn: Jeffrey Campbell
1810 West Sunbury Road
West Sunbury, PA 16061

Work Order: 0081873
Project: Wastewater
Project Description: Wastewater

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
Effluent Outfall 001	0081873-01	Waste Water	08/20/2020 12:00	8/20/20 14:20	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

TKN subcontracted to Suburban Water Testing Laboratory-Reading, PA DEP Lab ID 06-00208; please see attached subcontract laboratory Report of Analysis for results.

Definitions

- G CBOD / BOD result may be biased low due to GGA standard falling below laboratory acceptance criteria.
- C CBOD/ BOD dilutions did not meet method criteria of 1.0 mg/L final DO and/or 2.0 mg/L loss (depletion); results are estimated.
- RL Reporting Limit
- CFU Colony Forming Units

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

Environmental Service Laboratories, Inc., Indiana, PA/TNI Certification #32-00382

Approved By

Rebecca Erwin
Project Manager





1803 Philadelphia Street
 Indiana, PA 15701
 P: (724) 463-8378
 F: (724) 465-4209
 PADEP: 32-00382

1276 Bentleyville Road
 Van Voorhis, PA 15366
 P: (724) 258-8378
 F: (724) 258-8376
 PADEP: 63-04247

435 Broad Street
 Montoursville, PA 17754
 P: (570) 321-9002
 F: (570) 321-1957
 PADEP: 41-04880

950 West Main Street
 Sharpsville, PA 16150
 P: (724) 463-8378 x 500
 F: (724) 465-4209
 PADEP: 43-04934

Moniteau School District
 1810 West Sunbury Road
 West Sunbury, PA 16061

Reported: 09/03/2020 09:31

Lab Sample ID#: 0081873-01
Sample Type: Waste Water
Sample Source: Grab
Sampler: Client
Client Sample ID: Effluent Outfall 001

Sample Date: 08/20/2020 12:00
Receipt Date: 08/20/2020 14:20

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
General Chemistry	Analytical Method: CALC				Prep Method: [CALC]		
Total Nitrogen	7.05	mg/L		0.520	DAA	08/25/20 17:15	08/27/20 14:11
General Chemistry	Analytical Method: SM2540 D-11				Prep Method: No Prep - WetChem		
Total Suspended Solids	<5	mg/L		5	LMB	08/26/20 11:43	08/26/20 13:00
General Chemistry	Analytical Method: SM4500-NO3 E-11 (discrete)				Prep Method: No Prep - WetChem		
Nitrate/Nitrite	6.42	mg/L		0.520	DAA	08/25/20 17:15	08/27/20 14:11
General Chemistry	Analytical Method: SM4500-P E-11				Prep Method: No Prep - WetChem		
Phosphorus	1.4	mg/L		0.20	JPD	08/30/20 10:09	08/30/20 10:30
General Chemistry	Analytical Method: SM5210 B-11				Prep Method: No Prep - WetChem		
Carbonaceous Biochemical Oxygen Demand	<3.00	mg/L	C, G	3.00	AW	08/21/20 13:15	08/26/20 09:44
Microbiology	Analytical Method: Colilert-18				Prep Method: No Prep - Micro		
Fecal Coliforms	<1	MPN/100 mL		1	RAE	08/20/20 16:20	08/21/20 10:27


ENVIRONMENTAL SERVICE LABORATORIES, INC.

SAMPLE REQUEST & CHAIN OF CUSTODY

HEADQUARTERS
1803 Philadelphia St.
Indiana, PA 15701
(724) 463-TEST
FAX: (724) 465-4209

SOUTHERN DIVISION
1276 Bentleyville Road
Van Voorhis, PA 15366
(724) 258-TEST
FAX: (724) 258-8376

NORTHERN DIVISION
435 Broad Street
Monaca
(570) 5
FAX: (



NORTHWEST DIVISION
in Street
ille, PA 16150
3-TEST
(24) 465-4209



FOR INTERNAL LABORATORY

Sample Identification	ESL#	Sample Type		Matrix	# of Containers	Container Type	Analysis Requested
		Composite	Grab				
		Date on/off	Time on/off	Date	Time		
Effluent Outfall 001		8/20/20	12:00		1	Poly 1000mL	CBOD, TSS
		8/20/20	12:00		1	None	7
		8/20/20	12:00		1	H2SO4	Total Nitrogen, Total Phosphorus
					1	Sterile Plastic 125mL Na2S2O3	Fecal Coliform

Project Notes:
Wastewater

Company/Name: **MONITEAU SCHOOL DISTRICT**

Contact Person: **JEFFREY CAMPBELL**

Address: **1810 WEST SUNBURY ROAD**
WEST SUNBURY, PA 16061
724-406-4426
Email: jcampbell@moniteau.k12.pa.us

Received By: (Signature) *[Signature]* Date/ Time *8/20/20 12:00*

Relinquished By: (Signature) *[Signature]* Date/ Time *8/20/20 14:30*

Correct Preservations Y/N/NA *Y/N/NA* Correct Containers Y/N/NA *Y/N/NA* Receipt Temperature *[Blank]*

THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.
1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.)
2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.



SAMPLE RECEIPT AND REVIEW FORM

PART A: General Information



Client: <u>Moniteau</u>		Work Order: _____	
Received by: <u>JPD</u>	Date/Time Received: <u>8/20/20</u> <u>14:20</u>	Date Sampled: <u>8/20/20</u>	
Method of Delivery: FedEx UPS Client Drop off <u>ESL courier</u> Other: _____			
Sample Receipt Temp: <u>3.9</u>	Samples Received on Ice: <input checked="" type="radio"/> YES NO		
IR Gun # Used: 1 2 <u>3</u> 4			
Samples Removed by Satellite Lab Division: Southern(BV) NorthWest(NW) Northern(WP)	Containers removed by Satellite Lab for analysis of:	TCMPN	Fecal Coliform TC/EC
Sample State of Collection: <input checked="" type="radio"/> PA NY OH WV Other: _____	PWSID COMPLIANCE DRINKING WATER SAMPLES: YES <input checked="" type="radio"/> NO		

PART B: Receipt Details

Completed (if different from above): _____ / ____ / ____
Signature Date Time

Sample Receipt Criteria					Comments/Qualifiers (Required for Non-Conforming Items)	Deficiency Log Required	
1	Chain of custody documents included with samples?	Yes	No	N/A	Comments:	YES	NO
2	COC form is properly signed in relinquished/received sections?	Yes	No	N/A	Comments:	YES	NO
3	Sample containers intact and sealed?	Yes	No	N/A	Circle Applicable: Damaged container Leaking container Custody Seal Broken Other: _____	YES	NO
4	Number of containers received match number indicated on COC?	Yes	No	N/A	Sample ID's affected:	YES	NO
5	Sample ID's on COC match ID's on bottles?	Yes	No	N/A	Sample ID's and containers affected:	YES	NO
6	Date and time on COC match date and time on bottles?	Yes	No	N/A	Sample ID's affected:	YES	NO
7	Samples received within holding time?	Yes	No	N/A	ID's and tests affected:	YES	NO
8	Samples received at appropriate pH for analysis requested?	Yes	No	N/A	Sample ID's, containers affected and observed pH:	YES	NO
9	Samples requiring thermal preservation within 0 ≤ 6°C? Microbiology within 0 ≤ 10°C?	Yes	No	N/A	For non-WV samples outside of thermal preservation range sampled same day and received on ice are considered acceptable condition as the cooling process has begun.	YES	NO
11	Adequate sample volume received?	Yes	No	N/A	Analyses Affected:	YES	NO
10	VOA vials free of headspace (defined as < 6mm bubble)?	Yes	No	<u>N/A</u>	Sample ID's and containers affected:	YES	NO
Other Comments:						Deficiency Log Created:	
						Yes	<input checked="" type="radio"/> No



Results Report

Order ID: 0084893

Environmental Service Laboratories, Inc. 1803 Philadelphia Street Indiana, PA 15701	Project: TKN Testing
Attn: Accounts Payable	Regulatory ID:

Sample Number: 0084893-01	Site: 0081873-01	Sample ID: 0081873
Collector: Client	Collect Date: 08/20/2020 12:00 pm	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By	
Inorganics										
Total Kjeldahl Nitrogen (TKN)	0.63	B	mg/L	EPA 351.2	0.50	1	08/31/20	CJ	09/02/20 11:43	DWL

Data Qualifiers:

B The target analyte was detected in the Method, Dilution Water, Instrument or Extraction Blank or Sterility Check at or above the method Reporting Limit or applicable method, client, or regulatory requirement.

Sample Receipt Conditions:

All samples met the sample receipt requirements for the relevant analyses.

The test *pH, Lab* is performed in the Laboratory as soon as possible. These results are not appropriate for compliance with NPDES, SDWA, or other regulatory programs that require analysis within 15 minutes of sample collection and should be considered for informational purposes only.

**pH, Final* for ASTM leachate is performed by method SM 4500-H-B.

All results meet the requirements of STL's TNI (NELAC) Accredited Quality System unless otherwise noted. If your results contain any data qualifiers or comments, you should evaluate useability relative to your needs.

If collectors initials include "STL", samples have been collected in accordance with STL SOP SL0015.

All results reported on an As Received (Wet Weight) basis unless otherwise noted.

This laboratory report may not be reproduced, except in full, without the written approval of STL.

Results are considered Preliminary unless report is signed by authorized representative of STL.

Reviewed and Released By:

Lisa F. Care
Project Manager I

Report Generated On: 09/02/2020 4:23 pm 0084893
STL_Results Revision #1.9 Effective: 04/16/2020



SUBCONTRACT C
Environmental Service Lab
0081873



Please report all results to reports@envlabs.com

SENDING LABORATORY:

Environmental Service Laboratories, Inc.
1803 Philadelphia Street
Indiana, PA 15701
Phone: 724-463-8378
Fax: 724-465-4209
Project Manager: Rebecca Erwin

RECEIVING LABORATORY:

Suburban Water Testing Labs - Reading
1037F MacArthur Road
Reading, PA 19605
Phone: (610) 375-8378
Fax: 1610-375-4090

State of Origin: PA

Analysis	Due	Expires	Comments
Sample ID: 0081873-01			
Matrix: Water	Sampled: 08/20/2020 12:00	Sample Type: Grab	Sampled By: Client
Total Kjeldahl Nitrogen	09/01/2020 23:00	09/17/2020 12:00	
Containers Supplied: Poly 250mL, H2SO4 (D) <i>PHS2 AN13</i>			

Suburban Testing Labs

Lab Date/Time: *8/21/2010* Lab Temp: *1.4°C*
 Number of containers/coolers match number on COC? Y N
 Sample labels and COC are free of discrepancies? Y N
 All containers in tact? Y N
 Received in lab within acceptable temperature limits? Y N
 40mL VOA vials free of headspace? Y N
 Relinquished by: *Delivery*
 Received in Lab by: *JM* *1.4°C*

Released By: *[Signature]* Date: *8/21/2010* Received By: _____ Date: _____

Released By: _____ Date: _____ Received By: _____ Date: _____



**Moniteau School District
Maintenance Department
Moniteau High School
Water Treatment Plant
Monthly Operations Report for
August 2020**

MONTEAU HIGH SCHOOL WATER TREATMENT PLANT												
MONTH	DAY	TEMP	LEVEL	METER READING	CL2 FREE	CL2 TOTAL	PH	IRON	MAG.	HARDNESS	OPERATOR	TIME
August 2020	1	SAT										
	2	SUN										
	3	Mon	74.7	8.10	3,661,199	0.56	0.62	7.5	0.01	0	JEFF C	7:00 AM
	4	Tues	75.0	7.40	3,661,199	0.57	0.62	7.5	0.01	0	JEFF C	7:30 AM
	5	Wed	75.0	7.27	3,661,199	0.56	0.61	7.6	0.01	0	JEFF C	11:00 AM
	6	Thurs	75.6	6.88	3,661,199	0.55	0.59	7.5	0.01	0	JEFF C	9:20 AM
	7	Fri	75.0	7.99	3,668,094	0.56	0.61	7.4	0.00	0	JEFF C	7:00 AM
	8	SAT										
	9	SUN										
	10	Mon	76.2	6.14	3,668,094	0.48	0.50	7.4	0.00	0	JEFF C	9:00 AM
	11	Tues	75.9	7.57	3,676,600	0.38	0.42	7.4	0.00	0	JEFF C	2:30 PM
	12	Wed	77.7	6.95	3,676,600	0.35	0.40	7.4	0.00	0	JEFF C	08:00 AM
	13	Thurs	79.8	6.68	3,676,600	0.32	0.37	7.5	0.01	0	JEFF C	04:00 AM
	14	Fri	76.6	7.76	3,690,580	0.87	1.00	7.5	0.00	0	JEFF C	5:30 PM
	15	SAT										
	16	SUN										
	17	Mon	76.0	6.24	3,690,580	0.84	0.95	7.6	0.01	0	JEFF C	09:00 AM
	18	Tues	72.9	6.62	3,695,277	0.85	0.95	7.5	0.01	0	JEFF C	10:00 AM
	19	Wed	73.0	6.08	3,695,277	0.85	0.93	7.5	0.01	0	JEFF C	09:00 AM
	20	Thurs	69.9	9.80	3,715,724	0.77	0.89	7.5	0.02	0	JEFF C	1:30 PM
	21	Fri	70.0	8.95	3,715,724	0.74	0.87	7.5	0.02	0	JEFF C	11:30 AM
	22	SAT										
	23	SUN										
	24	Mon	75.6	8.26	3,715,724	0.75	0.88	7.5	0.01	0	JEFF C	11:00 AM
	25	Tues	77.5	7.43	3,715,724	0.83	1.00	7.5	0.01	0	JEFF C	08:30 AM
	26	Wed	79.0	7.04	3,715,724	0.74	0.85	7.5	0.01	0	JEFF C	4:30 PM
	27	Thurs	80.0	6.16	3,715,724	0.67	0.71	7.5	0.01	0	JEFF C	5:36 PM
	28	Fri	80.3	6.02	3,715,724	0.68	0.73	7.5	0.01	0	JEFF C	8:00 AM
	29	SAT										
	30	SUN										
	31	Mon	73.1	8.64	3,725,182	1.08	1.15	7.5	0.00	0	JEFF C	10:30 AM

THAM
HAAS
LEAD +
Copper



1803 Philadelphia Street
 Indiana, PA 15701
 P: (724) 463-8378
 F: (724) 465-4209
 PADEP: 32-00382

1276 Bentleyville Road
 Van Voorhis, PA 15366
 P: (724) 258-8378
 F: (724) 258-8376
 PADEP: 63-04247

435 Broad Street
 Montoursville, PA 17754
 P: (570) 321-9002
 F: (570) 321-1957
 PADEP: 41-04880

950 West Main Street
 Sharpsville, PA 16150
 P: (724) 463-8378 x 500
 F: (724) 465-4209
 PADEP: 43-04934

17 August 2020

Moniteau School District
 Attn: Jeffrey Campbell
 1810 West Sunbury Road
 West Sunbury, PA 16061

Work Order: 0080615
Project: Drinking Water Moniteau Jr/Sr - Monthly 802
Project Description: Drinking Water

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
802 Room 204 Sink	0080615-01	Drinking Water	08/06/2020 12:50	8/6/20 15:00	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.
 Environmental Service Laboratories, Inc., Indiana, PA/TNI Certification #32-00382

Approved By

Rebecca Erwin
 Project Manager





1803 Philadelphia Street
 Indiana, PA 15701
 P: (724) 463-8378
 F: (724) 465-4209
 PADEP: 32-00382

1276 Bentleyville Road
 Van Voorhis, PA 15366
 P: (724) 258-8378
 F: (724) 258-8376
 PADEP: 63-04247

435 Broad Street
 Montoursville, PA 17754
 P: (570) 321-9002
 F: (570) 321-1957
 PADEP: 41-04880

950 West Main Street
 Sharpsville, PA 16150
 P: (724) 463-8378 x 500
 F: (724) 465-4209
 PADEP: 43-04934

Moniteau School District
 1810 West Sunbury Road
 West Sunbury, PA 16061

Reported: 08/17/2020 09:12

Lab Sample ID#: 0080615-01
Sample Type: Drinking Water
Sample Source: Grab
Sampler: Paul Somogyi
Client Sample ID: 802 Room 204 Sink

Sample Date: 08/06/2020 12:50
Receipt Date: 08/06/2020 15:00

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/Certification	Prep Date/Time	Analysis Date/Time
Field Analysis		Analytical Method: SM4500-Cl G-11			Prep Method: No Prep - Field		
Chlorine, Free	0.530	mg/L		0.200	PFS	08/06/20 12:50	08/06/20 12:50
Microbiology		Analytical Method: SM9223 B-04			Prep Method: No Prep - Micro		
Total Coliform	Absent	per 100 mL		1	DAA	08/06/20 16:06	08/07/20 17:51
E. Coli	Absent	per 100 mL		1	DAA	08/06/20 16:06	08/07/20 17:51

This sample MEETS current EPA and DEP bacteriological standards of no detectable coliform bacteria per 100 mL sample.

ENVIRONMENTAL SERVICE LABORATORIES, INC.

HEADQUARTER
1803 Philadelphia St.
Indiana, PA 15701
(724) 463-TEST
FAX: (724) 465-4209

SOUTHERN DIVISION
1276 Benfleyville Road
Van Voorhis, PA 15366
(724) 258-TEST
FAX: (724) 258-8376

NORTHERN DIVISI
435 Broad Street
Montoursville, PA 17
(570) 321-9003
FAX: (570) 321-1957



FAX: (724) 465-4209

FOR INTERNAL LABORATORY USE ONLY

SAMPLE REQUEST & CHAIN OF CUSTODY

3E 1 OF 1

Sample Identification	ESL#	Sample Type	Matrix	# of Bottles	Container Type Preservative	Analysis Requested
	704 KITCHEN MAIN SINK 802 ROOM 204 SINK	Grab				
CIRCLE ONE:		Date	DW	1		
		8/6/20		✓		53
704: Jan, Mar, May, Jul, Sept, Nov						
802: Feb, Apr, Jun, Aug, Oct, Dec						
THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.						
1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.)						
2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.						
Sampled By: (Signature)	Date/ Time	Received By: (Signature)	Date/ Time	Notes/Special Instructions:		
	8/6/20 12:50		8/6/20 13:00	Drinking Water Moniteau Jr/Sr - Monthly		
Relinquished By: (Signature)	Date/ Time	Received By: (Signature)	Date/ Time	Company Name: MONITEAU SCHOOL DISTRICT		
				Address: 1810 WEST SUNBURY ROAD		
				Contact Person: WEST SUNBURY, PA 16061		
				Phone Number: JEFFREY CAMPBELL		
				Cell Phone: 724-406-4426		
				Email Address: jcampbell@moniteau.k12.pa.us		
				Billing Address:		
				PWSID: 5100324		
Correct Preservations Y / N / NA	Correct Containers Y / N / NA	Receipt Temperature				
		3.0				



E-Government Application for Drinking Water Program

SAFE DRINKING WATER ACT
VIEW/EDIT RECORDS

5100324: MONITEAU JR/SR HIGH SCHOOL

SDWA1

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100324	1013	FREE CHLORINE	301	0.53	080620	802		080620	D	1250	32382	0080615-01	BROWNKA_80
5100324	3100	TOTAL COLIFORM PRESENCE	331	0.0	080720	802		080620	D	1250	32382	0080615-01	BROWNKA_81

5100324: MONITEAU JR/SR HIGH SCHOOL

SDWA4

PWSID	Contam ID	Contam	Analysis Method	Result	Lower Limit of Detection	Counting Error	Analysis Date	Loc/EP ID	Loc/EP ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100324	1040	NITRATE	120	0.0	0.10000		080820	101		080620	E	1250	32382	0080600-01	BROWNKA_261
5100324	1041	NITRITE	120	0.0	0.10000		080820	101		080620	E	1250	32382	0080600-01	BROWNKA_262



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

13 August 2020

Moniteau School District
Attn: Jeffrey Campbell
1810 West Sunbury Road
West Sunbury, PA 16061

Work Order: 0081232
Project: Drinking Water Moniteau Jr/Sr - Weekly
Project Description: Drinking Water

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
802 Room 204 Sink	0081232-01	Drinking Water	08/13/2020 12:00	8/13/20 14:18	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

Approved By

Rebecca Erwin
Project Manager



1803 Philadelphia Street
 Indiana, PA 15701
 P: (724) 463-8378
 F: (724) 465-4209
 PADEP: 32-00382

1276 Bentleyville Road
 Van Voorhis, PA 15366
 P: (724) 258-8378
 F: (724) 258-8376
 PADEP: 63-04247

435 Broad Street
 Montoursville, PA 17754
 P: (570) 321-9002
 F: (570) 321-1957
 PADEP: 41-04880

950 West Main Street
 Sharpville, PA 16150
 P: (724) 463-8378 x 500
 F: (724) 465-4209
 PADEP: 43-04934

Moniteau School District
 1810 West Sunbury Road
 West Sunbury, PA 16061

Reported: 08/13/2020 17:22

Lab Sample ID#: 0081232-01
Sample Type: Drinking Water
Sample Source: Grab
Sampler: Paul Somogyi
Client Sample ID: 802 Room 204 Sink

Sample Date: 08/13/2020 12:00
Receipt Date: 08/13/2020 14:18

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/Certification	Prep Date/Time	Analysis Date/Time
Field Analysis	Analytical Method: SM4500-Cl G-11				Prep Method: No Prep - Field		
Chlorine, Free	1.00	mg/L		0.200	PFS	08/13/20 12:00	08/13/20 12:00

ENVIRONMENTAL SERVICE LABORATORIES, INC.

HEADQUARTER
1803 Philadelphia St.
Indiana, PA 15701
(724) 463-TEST
FAX: (724) 465-4209

SOUTHERN DIVISION
1276 Bentleyville Road
Van Voorhis, PA 15366
(724) 258-TEST
FAX: (724) 258-8376

NORTHERN DIVISION
435 Broad St.
Monitorsville, F
(570) 321-9003
FAX: (570) 321



0081232

FOR INTERNAL LABORATORY USE ONLY

Sample Identification	ESL#	Sample Type		# of Bottles	Matrix	Container Type	Analysis Requested
		Grab	Time				
Distribution: <u>802</u>	<u>0081732</u>			Field	DW	Field	Free Chlorine <u>1.68</u> mg/L
	<u>01</u>		<u>1200</u>				
<p>ROTATION</p> <p>Wk 1 - 704 Kitchen Sink</p> <p>Wk 2 - 802 Room 204 Sink</p> <p>Wk 3 - 803 Admin Sink</p> <p>Wk 4 - 804 400 Hall RR Sink</p> <p>Wk 5 - 804 400 Hall RR Sink</p>							
<p>Notes/Special Instructions: <u>Drinking Water Moniteau Jr/Sr - Weekly</u></p>							
<p>1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.)</p> <p>2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.</p>							
Sampled By: (Signature) <u>[Signature]</u> Date/ Time <u>8/13/06 1400</u>		Received By: (Signature) <u>[Signature]</u> Date/ Time <u>8/15/06 1410</u>				Company Name: <u>MONITEAU SCHOOL DISTRICT</u>	
Relinquished By: (Signature) Date/ Time		Received By: (Signature) Date/ Time				Address: <u>391 HOOKER ROAD</u> <u>WEST SUNBURY, PA 16061</u>	
Relinquished By: (Signature) Date/ Time		Received By: (Signature) Date/ Time				Contact Person: <u>JEFFREY CAMPBELL</u>	
Relinquished By: (Signature) Date/ Time		Received By: (Signature) Date/ Time				Cell Phone: <u>724-406-4426</u>	
Relinquished By: (Signature) Date/ Time		Received By: (Signature) Date/ Time				Email Address: <u>jcampbell@moniteau.k12.pa.us</u>	
Correct Preservations Y/N/NA		Correct Containers Y/N/NA				Billing Address: <u>5100324</u>	
						PWSID:	



E-Government Application for Drinking Water Program
SAFE DRINKING WATER ACT
 VIEW/EDIT RECORDS

5100324: MONITEAU JR/SR HIGH SCHOOL

SDWA1

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100324	1013	FREE CHLORINE	301	0.53	080620	802		080620	D	1250	32382	0080615-01	BROWNKA_80
5100324	1013	FREE CHLORINE	301	1.0	081320	802		081320	D	1200	32382	0081232-01	BROWNKA_627
5100324	3100	TOTAL COLIFORM PRESENCE	331	0.0	080720	802		080620	D	1250	32382	0080615-01	BROWNKA_81

5100324: MONITEAU JR/SR HIGH SCHOOL

SDWA4

PWSID	Contam ID	Contam	Analysis Method	Result	Lower Limit of Detection	Counting Error	Analysis Date	Loc/EP ID	Loc/EP ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100324	1040	NITRATE	120	0.0	0.10000		080820	101		080620	E	1250	32382	0080600-01	BROWNKA_261
5100324	1041	NITRITE	120	0.0	0.10000		080820	101		080620	E	1250	32382	0080600-01	BROWNKA_262



1803 Philadelphia Street
 Indiana, PA 15701
 P: (724) 463-8378
 F: (724) 465-4209
 PADEP: 32-00382

1276 Bentleyville Road
 Van Voorhis, PA 15366
 P: (724) 258-8378
 F: (724) 258-8376
 PADEP: 63-04247

435 Broad Street
 Montoursville, PA 17754
 P: (570) 321-9002
 F: (570) 321-1957
 PADEP: 41-04880

950 West Main Street
 Sharpsville, PA 16150
 P: (724) 463-8378 x 500
 F: (724) 465-4209
 PADEP: 43-04934

20 August 2020

Moniteau School District
 Attn: Jeffrey Campbell
 1810 West Sunbury Road
 West Sunbury, PA 16061

Work Order: 0081882
Project: Drinking Water Moniteau Jr/Sr - Weekly
Project Description: Drinking Water

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
803 Admin Sink	0081882-01	Drinking Water	08/20/2020 11:50	8/20/20 14:32	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

Approved By

Rebecca Erwin
 Project Manager



1803 Philadelphia Street
 Indiana, PA 15701
 P: (724) 463-8378
 F: (724) 465-4209
 PADEP: 32-00382

1276 Bentleyville Road
 Van Voorhis, PA 15366
 P: (724) 258-8378
 F: (724) 258-8376
 PADEP: 63-04247

435 Broad Street
 Montoursville, PA 17754
 P: (570) 321-9002
 F: (570) 321-1957
 PADEP: 41-04880

950 West Main Street
 Sharpsville, PA 16150
 P: (724) 463-8378 x 500
 F: (724) 465-4209
 PADEP: 43-04934

Moniteau School District
 1810 West Sunbury Road
 West Sunbury, PA 16061

Reported: 08/20/2020 16:56

Lab Sample ID#: 0081882-01
Sample Type: Drinking Water
Sample Source: Grab
Sampler: Justin Matava
Client Sample ID: 803 Admin Sink

Sample Date: 08/20/2020 11:50
Receipt Date: 08/20/2020 14:32

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/Certification	Prep Date/Time	Analysis Date/Time
Field Analysis		Analytical Method: SM4500-Cl G-11			Prep Method: No Prep - Field		
Chlorine, Free	0.900	mg/L		0.200	JDM	08/20/20 11:50	08/20/20 11:50



E-Government Application for Drinking Water Program
SAFE DRINKING WATER ACT
 VIEW/EDIT RECORDS

5100324: MONITEAU JR/SR HIGH SCHOOL

SDWA1

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100324	2943	BROMODICHLOROMETHANE (THM)	221	0.0111	081420	704		081020	D	0800	32382	0080842-02	BROWNKA_1083
5100324	1013	FREE CHLORINE	301	0.53	080620	802		080620	D	1250	32382	0080615-01	BROWNKA_80
5100324	1013	FREE CHLORINE	301	1.0	081320	802		081320	D	1200	32382	0081232-01	BROWNKA_627
5100324	3100	TOTAL COLIFORM PRESENCE	331	0.0	080720	802		080620	D	1250	32382	0080615-01	BROWNKA_81
5100324	1013	FREE CHLORINE	301	0.9	082020	803		082020	D	1150	32382	0081882-01	BROWNKA_1409

5100324: MONITEAU JR/SR HIGH SCHOOL

SDWA4

PWSID	Contam ID	Contam	Analysis Method	Result	Lower Limit of Detection	Counting Error	Analysis Date	Loc/EP ID	Loc/EP ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100324	1040	NITRATE	120	0.0	0.10000		080820	101		080620	E	1250	32382	0080600-01	BROWNKA_261
5100324	1041	NITRITE	120	0.0	0.10000		080820	101		080620	E	1250	32382	0080600-01	BROWNKA_262
5100324	2378	1,2,4-TRICHLOROBENZE	221	0.0	0.00050		081220	101		080620	E	1250	32382	0080599-01	BROWNKA_692
5100324	2380	cis-1,2-DICHLOROETHYLENE	221	0.0	0.00050		081220	101		080620	E	1250	32382	0080599-01	BROWNKA_694
5100324	2955	XYLENES (TOTAL)	221	0.0	0.00050		081220	101		080620	E	1250	32382	0080599-01	BROWNKA_696
5100324	2964	DICHLOROMETHANE	221	0.0	0.00050		081220	101		080620	E	1250	32382	0080599-01	BROWNKA_698
5100324	2968	o-DICHLOROBENZENE	221	0.0	0.00050		081220	101		080620	E	1250	32382	0080599-01	BROWNKA_700
5100324	2969	PARA-DICHLOROBENZENE	221	0.0	0.00050		081220	101		080620	E	1250	32382	0080599-01	BROWNKA_702
5100324	2976	VINYL CHLORIDE	221	0.0	0.00050		081220	101		080620	E	1250	32382	0080599-01	BROWNKA_704
5100324	2977	1,1-DICHLOROETHYLENE	221	0.0	0.00050		081220	101		080620	E	1250	32382	0080599-01	BROWNKA_706



E-Government Application for Drinking Water Program

SAFE DRINKING WATER ACT
VIEW/EDIT RECORDS

**5100324: MONITEAU JR/SR HIGH SCHOOL
SDWA4**

PWSID	Contam ID	Contam	Analysis Method	Result	Lower Limit of Detection	Counting Error	Analysis Date	Loc/EP ID	Loc/EP ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100324	2979	trans-1,2-DICHLOROETHYLENE	221	0.0	0.00050		081220	101		080620	E	1250	32382	0080599-01	BROWNKA 708
5100324	2980	1,2-DICHLOROETHANE	221	0.0	0.00050		081220	101		080620	E	1250	32382	0080599-01	BROWNKA 710
5100324	2981	1,1,1-TRICHLOROETHANE	221	0.0	0.00050		081220	101		080620	E	1250	32382	0080599-01	BROWNKA 712
5100324	2982	CARBON TETRACHLORIDE	221	0.0	0.00050		081220	101		080620	E	1250	32382	0080599-01	BROWNKA 714
5100324	2983	1,2-DICHLOROPROPANE	221	0.0	0.00050		081220	101		080620	E	1250	32382	0080599-01	BROWNKA 716
5100324	2984	TRICHLOROETHYLENE	221	0.0	0.00050		081220	101		080620	E	1250	32382	0080599-01	BROWNKA 718
5100324	2985	1,1,2-TRICHLOROETHANE	221	0.0	0.00050		081220	101		080620	E	1250	32382	0080599-01	BROWNKA 720
5100324	2987	TETRACHLOROETHYLENE	221	0.0	0.00050		081220	101		080620	E	1250	32382	0080599-01	BROWNKA 722
5100324	2989	CHLOROBENZENE	221	0.0	0.00050		081220	101		080620	E	1250	32382	0080599-01	BROWNKA 724
5100324	2990	BENZENE	221	0.0	0.00050		081220	101		080620	E	1250	32382	0080599-01	BROWNKA 726
5100324	2991	TOLUENE	221	0.0	0.00050		081220	101		080620	E	1250	32382	0080599-01	BROWNKA 728
5100324	2992	ETHYL BENZENE	221	0.0	0.00050		081220	101		080620	E	1250	32382	0080599-01	BROWNKA 730
5100324	2996	STYRENE	221	0.0	0.00050		081220	101		080620	E	1250	32382	0080599-01	BROWNKA 732

**ENVIRONMENTAL SERVICE
LABORATORIES, INC.**

HEADQUARTER
1803 Philadelphia St.
Indiana, PA 15701
(724) 463-TEST
FAX: (724) 465-4209

SOUTHERN DIVISION
1276 Bentleyville Road
Van Voorhis, PA 15366
(724) 258-TEST
FAX: (724) 258-8376



0081882

NORTHWEST DIVISION
950 Main Street
Sharpsville, PA 16
(724) 463-TEST
FAX: (724) 465-4209

SAMPLE REQUEST & CHAIN OF CUSTODY

3E 1 OF 1

FOR INTERNAL LABORATORY USE ONLY

Sample Identification	ESL#	Sample Type		Matrix	# of Bottles	Container Type	Analysis Requested
		Date	Time				
Distribution: _____	0081882	8/20/20	1150	DW	Field	Field	Free Chlorine 0.90 mg/L
<p>ROTATION</p> <p>Wk 1 - 704 Kitchen Sink</p> <p>Wk 2 - 802 Room 204 Sink</p> <p>Wk 3 - 803 Admin Sink</p> <p>Wk 4 - 804 400 Hall RR Sink</p> <p>Wk 5 - 804 400 Hall RR Sink</p>							
<p>THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.</p> <p>1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW).</p> <p>2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.</p>							
<p>Sampled By: (Signature) <i>[Signature]</i> Date/ Time 8/20/20 1150</p>				<p>Received By: (Signature) <i>[Signature]</i> Date/ Time 8/20/20 14:30</p>			
<p>Relinquished By: (Signature) _____ Date/ Time _____</p>				<p>Relinquished By: (Signature) _____ Date/ Time _____</p>			
<p>Relinquished By: (Signature) _____ Date/ Time _____</p>				<p>Relinquished By: (Signature) _____ Date/ Time _____</p>			
<p>Relinquished By: (Signature) _____ Date/ Time _____</p>				<p>Relinquished By: (Signature) _____ Date/ Time _____</p>			
<p>Correct Preservations Y/N (NA)</p>				<p>Correct Containers Y/N (NA)</p>			
<p>Receipt Temperature _____</p>				<p>Receipt Temperature _____</p>			
<p>Notes/Special Instructions: Drinking Water Moniteau Jr/Sr - Weekly</p>							
<p>Company/Name: MONITEAU SCHOOL DISTRICT</p> <p>Address: 391 HOOKER ROAD WEST SUNBURY, PA 16061</p> <p>Contact Person: JEFFREY CAMPBELL</p> <p>Phone Number: 724-406-4426</p> <p>Cell Phone: jcampbell@moniteau.k12.pa.us</p> <p>Billing Address: 5100324</p> <p>PWSID: 5100324</p>							



1803 Philadelphia Street
 Indiana, PA 15701
 P: (724) 463-8378
 F: (724) 465-4209
 PADEP: 32-00382

1276 Bentleyville Road
 Van Voorhis, PA 15366
 P: (724) 258-8378
 F: (724) 258-8376
 PADEP: 63-04247

435 Broad Street
 Montoursville, PA 17754
 P: (570) 321-9002
 F: (570) 321-1957
 PADEP: 41-04880

950 West Main Street
 Sharpsville, PA 16150
 P: (724) 463-8378 x 500
 F: (724) 465-4209
 PADEP: 43-04934

28 August 2020

Moniteau School District
 Attn: Jeffrey Campbell
 1810 West Sunbury Road
 West Sunbury, PA 16061

Work Order: 0082417
Project: Drinking Water Moniteau Jr/Sr - Weekly
Project Description: Drinking Water

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
804 400 Hall RR Sink	0082417-01	Drinking Water	08/27/2020 11:20	8/27/20 14:37	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

Approved By

Rebecca Erwin
 Project Manager



1803 Philadelphia Street
 Indiana, PA 15701
 P: (724) 463-8378
 F: (724) 465-4209
 PADEP: 32-00382

1276 Bentleyville Road
 Van Voorhis, PA 15366
 P: (724) 258-8378
 F: (724) 258-8376
 PADEP: 63-04247

435 Broad Street
 Montoursville, PA 17754
 P: (570) 321-9002
 F: (570) 321-1957
 PADEP: 41-04880

950 West Main Street
 Sharpsville, PA 16150
 P: (724) 463-8378 x 500
 F: (724) 465-4209
 PADEP: 43-04934

Moniteau School District
 1810 West Sunbury Road
 West Sunbury, PA 16061

Reported: 08/28/2020 11:54

Lab Sample ID#: 0082417-01
Sample Type: Drinking Water
Sample Source: Grab
Sampler: Paul Somogyi
Client Sample ID: 804 400 Hall RR Sink

Sample Date: 08/27/2020 11:20
Receipt Date: 08/27/2020 14:37

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
Field Analysis		Analytical Method: SM4500-Cl G-11			Prep Method: No Prep - Field		
Chlorine, Free	0.760	mg/L		0.200	PFS	08/27/20 11:20	08/27/20 11:20

ENVIRONMENTAL SERVICE LABORATORIES, INC.

HEADQUARTER
1803 Philadelphia St.
Indiana, PA 15701
(724) 463-TEST
FAX: (724) 465-4209

SOUTHERN DIVISION
1276 Bentleyville Road
Van Vorthis, PA 15366
(724) 258-TEST
FAX: (724) 258-8376

FOR INTERNAL LABO.

SAMPLE REQUEST & CHAIN OF CUSTODY

RE 1 OF 1

WEST DIVISION
Street
e, PA 16
TEST
(724) 465-4209



Sample Identification	ESL# 0082417	Sample Type Grab	Matrix	# of Bottles	Container Type Preservative	Analysis Requested
Distribution: 804	ca	Date 8/27/20	DW	Field	Field	Free Chlorine 0.76 mg/L
<p>ROTATION</p> <p>Wk 1 - 704 Kitchen Sink</p> <p>Wk 2 - 802 Room 204 Sink</p> <p>Wk 3 - 803 Admin Sink</p> <p>Wk 4 - 804 400 Hall RR Sink</p> <p>Wk 5 - 804 400 Hall RR Sink</p>						
<p>Notes/Special Instructions:</p> <p>Drinking Water Moniteau Jr/Sr - Weekly</p>						
<p>1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1.12% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.)</p> <p>2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.</p>						
Sampled By: (Signature)	8/27/20	Date/ Time	1120			
Relinquished By: (Signature)	8/27/20	Date/ Time	1330			
Relinquished By: (Signature)		Date/ Time				
Relinquished By: (Signature)		Date/ Time				
Correct Preservations Y/N (NA)	Y/N (NA)	Correct Containers Y/N (NA)	Y/N (NA)	Receipt Temperature		
<p>Company Name: MONITEAU SCHOOL DISTRICT</p> <p>Address: 391 HOOKER ROAD WEST SUNBURY, PA 16061</p> <p>Contact Person: JEFFREY CAMPBELL</p> <p>Phone Number: 724-406-4426</p> <p>Cell Phone: jcampbell@moniteau.k12.pa.us</p> <p>Billing Address: 5100324</p> <p>PWSID: 5100324</p>						

**5100324: MONITEAU JR/SR HIGH SCHOOL
SDWA1**

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100324	2943	BROMODICHLOROMETHANE (THM)	221	0.0111	081420	704		081020	D	0800	32382	0080842-02	BROWNKA_1083
5100324	1013	FREE CHLORINE	301	0.53	080620	802		080620	D	1250	32382	0080615-01	BROWNKA_80
5100324	1013	FREE CHLORINE	301	1.0	081320	802		081320	D	1200	32382	0081232-01	BROWNKA_627
5100324	3100	TOTAL COLIFORM PRESENCE	331	0.0	080720	802		080620	D	1250	32382	0080615-01	BROWNKA_81
5100324	1013	FREE CHLORINE	301	0.9	082020	803		082020	D	1150	32382	0081882-01	BROWNKA_1409
5100324	1013	FREE CHLORINE	301	0.76	082720	804		082720	D	1120	32382	0082417-01	BROWNKA_1934

**5100324: MONITEAU JR/SR HIGH SCHOOL
SDWA4**

PWSID	Contam ID	Contam	Analysis Method	Result	Lower Limit of Detection	Counting Error	Analysis Date	Loc/EP ID	Loc/EP ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100324	1040	NITRATE	120	0.0	0.10000		080820	101		080620	E	1250	32382	0080600-01	BROWNKA_261
5100324	1041	NITRITE	120	0.0	0.10000		080820	101		080620	E	1250	32382	0080600-01	BROWNKA_262
5100324	2378	1,2,4-TRICHLOROBENZENE	221	0.0	0.00050		081220	101		080620	E	1250	32382	0080599-01	BROWNKA_692
5100324	2380	cis-1,2-DICHLOROETHYLENE	221	0.0	0.00050		081220	101		080620	E	1250	32382	0080599-01	BROWNKA_694
5100324	2955	XYLENES (TOTAL)	221	0.0	0.00050		081220	101		080620	E	1250	32382	0080599-01	BROWNKA_696
5100324	2964	DICHLOROMETHANE	221	0.0	0.00050		081220	101		080620	E	1250	32382	0080599-01	BROWNKA_698
5100324	2968	o-DICHLOROBENZENE	221	0.0	0.00050		081220	101		080620	E	1250	32382	0080599-01	BROWNKA_700
5100324	2969	PARA-DICHLOROBENZENE	221	0.0	0.00050		081220	101		080620	E	1250	32382	0080599-01	BROWNKA_702
5100324	2976	VINYL CHLORIDE	221	0.0	0.00050		081220	101		080620	E	1250	32382	0080599-01	BROWNKA_704

E-Government Application for Drinking Water Program
SAFE DRINKING WATER ACT
VIEW/EDIT RECORDS

5100324: MONITEAU JR/SR HIGH SCHOOL
SDWA4

PWSID	Contam ID	Contam	Analysis Method	Result	Lower Limit of Detection	Counting Error	Analysis Date	Loc/EP ID	Loc/EP ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100324	2977	1,1-DICHLOROETHYLENE	221	0.0	0.00050		081220	101		080620	E	1250	32382	0080599-01	BROWNKA 706
5100324	2979	trans-1,2-DICHLOROETHYLENE	221	0.0	0.00050		081220	101		080620	E	1250	32382	0080599-01	BROWNKA 708
5100324	2980	1,2-DICHLOROETHANE	221	0.0	0.00050		081220	101		080620	E	1250	32382	0080599-01	BROWNKA 710
5100324	2981	1,1,1-TRICHLOROETHANE	221	0.0	0.00050		081220	101		080620	E	1250	32382	0080599-01	BROWNKA 712
5100324	2982	CARBON TETRACHLORIDE	221	0.0	0.00050		081220	101		080620	E	1250	32382	0080599-01	BROWNKA 714
5100324	2983	1,2-DICHLOROPROPANE	221	0.0	0.00050		081220	101		080620	E	1250	32382	0080599-01	BROWNKA 716
5100324	2984	TRICHLOROETHYLENE	221	0.0	0.00050		081220	101		080620	E	1250	32382	0080599-01	BROWNKA 718
5100324	2985	1,1,2-TRICHLOROETHANE	221	0.0	0.00050		081220	101		080620	E	1250	32382	0080599-01	BROWNKA 720
5100324	2987	TETRACHLOROETHYLENE	221	0.0	0.00050		081220	101		080620	E	1250	32382	0080599-01	BROWNKA 722
5100324	2989	CHLOROBENZENE	221	0.0	0.00050		081220	101		080620	E	1250	32382	0080599-01	BROWNKA 724
5100324	2990	BENZENE	221	0.0	0.00050		081220	101		080620	E	1250	32382	0080599-01	BROWNKA 726
5100324	2991	TOLUENE	221	0.0	0.00050		081220	101		080620	E	1250	32382	0080599-01	BROWNKA 728
5100324	2992	ETHYLBENZENE	221	0.0	0.00050		081220	101		080620	E	1250	32382	0080599-01	BROWNKA 730
5100324	2996	STYRENE	221	0.0	0.00050		081220	101		080620	E	1250	32382	0080599-01	BROWNKA 732