

**Moniteau School District
Maintenance Department
Monthly Operations Report for
July 2020
Dassa McKinney Elementary
School
Water Treatment Plant**

Dassa McKinney Elementary School Water Treatment Facility

2020

Month	Day	PH	Iron	Cl2 Free	Cl2 Total	Hardness	Meter Reading	Operator	Time	Notes
July	Wed	7.9	0.03	0.42	0.45	1.58	11961300	Jeff C	4:00 PM	100
	Thurs	7.9	0.03	0.43	0.46	1.61	11961300	Jeff C	4:30 PM	
	Fri	7.9	0.04	0.42	0.46	1.57	11961300	Jeff C	2:30 PM	
	Sat									
	Sun									
	Mon	7.9	0.05	0.42	0.46	1.67	11961400	Jeff R	2:00 P	100
	Tues	7.9	0.06	0.45	0.48	1.38	11962300	Jeff R	2:00 P	900
	Wed	7.9	0.04	0.40	0.46	1.50	11962500	Jeff R	2:00 P	200
	Thurs	7.8	0.04	0.48	0.53	1.59	11962800	Jeff R	2:00 P	300
	Fri	7.9	0.03	0.93	0.98	1.41	11965500	Jeff R	2:30 P	2700
	Sat	7.8	0.03	0.60	0.64	2.16	11965700	Jeff R	2:30 P	200
	Sun	7.9	0.04	0.60	0.65	2.23	11965900	Jeff R	2:00 P	200
	Mon	7.8	0.03	0.60	0.64	2.16	11965700	Jeff R	2:30 P	200
	Tues	7.9	0.04	0.60	0.65	2.23	11965900	Jeff R	2:00 P	200
	Wed	7.9	0.04	0.48	0.54	1.59	11966100	Jeff R	2:30 P	200
	Thurs	8.1	0.04	0.44	0.48	1.46	11966300	Jeff R	2:30 P	200
	Fri	7.9	0.03	0.46	0.52	1.54	11966500	Jeff R	2:30 P	200
	Sat									
	Sun									
	Mon	7.9	0.05	0.39	0.45	1.44	11966900	Jeff R	2:30 P	400
	Tues	7.9	0.02	0.74	0.79	1.60	11967000	Jeff R	2:00 P	100
	Wed	7.8	0.03	0.86	0.90	1.58	11967400	Jeff R	2:30 P	400
	Thurs	7.9	0.05	0.72	0.78	1.21	11967900	Jeff R	2:30 P	500
	Fri	7.8	0.05	0.65	0.69	1.10	11968100	Jeff R	2:30 P	200
	Sat									
	Sun									
	Mon	7.9	0.04	0.56	0.61	1.28	11968800	Jeff R	2:00 P	700
	Tues	7.8	0.03	0.52	0.55	1.33	11969100	Jeff R	2:30 P	300
	Wed	8.0	0.05	0.42	0.45	1.36	11969300	Jeff R	2:30 P	200
	Thurs	7.9	0.04	0.40	0.44	1.45	11969800	Jeff R	2:30 P	500
	Fri	8.0	0.00	0.82	0.87	1.04	11969900	Jeff R	2:00 P	100

Meter Reading on 6/30/20 11961200



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

30 July 2020

Moniteau School District
Attn: Jeffrey Campbell
1810 West Sunbury Road
West Sunbury, PA 16061

Work Order: 0072766
Project: Drinking Water Dassa McKinney - Weekly
Project Description: Drinking Water

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
802 Room 617 Sink	0072766-01	Drinking Water	07/30/2020 09:50	7/30/20 12:55	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

Approved By

Rebecca Erwin
Project Manager



1803 Philadelphia Street
 Indiana, PA 15701
 P: (724) 463-8378
 F: (724) 465-4209
 PADEP: 32-00382

1276 Bentleyville Road
 Van Voorhis, PA 15366
 P: (724) 258-8378
 F: (724) 258-8376
 PADEP: 63-04247

435 Broad Street
 Montoursville, PA 17754
 P: (570) 321-9002
 F: (570) 321-1957
 PADEP: 41-04880

950 West Main Street
 Sharpshville, PA 16150
 P: (724) 463-8378 x 500
 F: (724) 465-4209
 PADEP: 43-04934

Moniteau School District
 1810 West Sunbury Road
 West Sunbury, PA 16061

Reported: 07/30/2020 13:28

Lab Sample ID#: 0072766-01
Sample Type: Drinking Water
Sample Source: Grab
Sampler: Paul Somogyi
Client Sample ID: 802 Room 617 Sink

Sample Date: 07/30/2020 09:50
Receipt Date: 07/30/2020 12:55

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/Certification	Prep Date/Time	Analysis Date/Time
Field Analysis	Analytical Method: SM4500-Cl G-11		Prep Method: No Prep - Field				
Chlorine, Free	0.400	mg/L		0.200	PFS	07/30/20 09:50	07/30/20 09:50

ENVIRONMENTAL SERVICE LABORATORIES, INC.

HEADQUARTER
1803 Philadelphia St
Indiana, PA 15701
(724) 463-TEST
FAX: (724) 465-4209

SOUTHERN DIVISION
1276 Bentleyville Road
Van Voorhis, PA 15366
(724) 258-TEST
FAX: (724) 258-8376



NORTHERN I
435 Broad Str
Montoursville,
(570) 321-900.
FAX: (570) 321-1957

FAX: (724) 465-4209

FOR INTERNAL LABORATORY USE ONLY

SAMPLE REQUEST & CHAIN OF CUSTODY

Sample Identification	ESL#	Sample Type		Matrix	# of Bottles	Container Type Preservative	Analysis Requested
		Date	Time				
Distribution: <u>804</u>	<u>0072766</u>	<u>7-30-20</u>	<u>0950</u>	DW	Field	Field	Free Chlorine <u>4.63</u> mg/L

ROTATION
Wk 1 - 801 Kitchen Sink
Wk 2 - 802 Room 617 Sink
Wk 3 - 803 Room 606 Sink
Wk 4 - 804 Room 408 Sink
Wk 5 - 802 Room 617 Sink

Notes/Special Instructions: Drinking Water Dassa McKinney - Weekly

Company/Name: MONITEAU SCHOOL DISTRICT

Address: 391 HOOKER ROAD
WEST SUNBURY, PA 16061

Contact Person: JEFFREY CAMPBELL

Phone Number: 724-406-4426

Cell Phone: jcambell@moniteau.k12.pa.us

Billing Address: 5100316

PWSID: 5100316

1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1.12% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.)

2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

Sampled By: (Signature) [Signature] Date/ Time 7-30-20 0950

Relinquished By: (Signature) [Signature] Date/ Time 7-30-20 1257

Received By: (Signature) [Signature] Date/ Time 7/30/20 12:58

Received By: (Signature) _____ Date/ Time _____

Received By: (Signature) _____ Date/ Time _____

Received By: (Signature) _____ Date/ Time _____

Correct Preservations Y / N / NA Y / N / NA Correct Containers Y / N / NA Y / N / NA Receipt Temperature _____

**5100316: DASSA MCKINNEY ELEM SCHOOL
SDWA1**

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100316	1013	FREE CHLORINE	301	0.49	070220	801		070220	D	1145	32382	0070252-01	BROWNKA_65
5100316	3100	TOTAL COLIFORM PRESENCE	331	0.0	070320	801		070220	D	1145	32382	0070252-01	BROWNKA_66
5100316	1013	FREE CHLORINE	301	0.44	070920	802		070920	D	1145	32382	0070921-01	BROWNKA_67
5100316	1013	FREE CHLORINE	301	0.4	073020	802		073020	D	0950	32382	0072766-01	BROWNKA_2042
5100316	1013	FREE CHLORINE	301	0.52	071620	803		071620	D	1035	32382	0071605-01	BROWNKA_852
5100316	1013	FREE CHLORINE	301	0.6	072320	804		072320	D	1015	32382	0072234-01	BROWNKA_1546



1803 Philadelphia Street
 Indiana, PA 15701
 P: (724) 463-8378
 F: (724) 465-4209
 PADEP: 32-00382

1276 Bentleyville Road
 Van Voorhis, PA 15366
 P: (724) 258-8378
 F: (724) 258-8376
 PADEP: 63-04247

435 Broad Street
 Montoursville, PA 17754
 P: (570) 321-9002
 F: (570) 321-1957
 PADEP: 41-04880

950 West Main Street
 Sharpshville, PA 16150
 P: (724) 463-8378 x 500
 F: (724) 465-4209
 PADEP: 43-04934

23 July 2020

Moniteau School District
 Attn: Jeffrey Campbell
 1810 West Sunbury Road
 West Sunbury, PA 16061

Work Order: 0072234
Project: Drinking Water Dassa McKinney - Weekly
Project Description: Drinking Water

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
804 Room 408 Sink	0072234-01	Drinking Water	07/23/2020 10:15	7/23/20 13:30	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

Approved By

Rebecca Erwin
 Project Manager



1803 Philadelphia Street
 Indiana, PA 15701
 P: (724) 463-8378
 F: (724) 465-4209
 PADEP: 32-00382

1276 Bentleyville Road
 Van Voorhis, PA 15366
 P: (724) 258-8378
 F: (724) 258-8376
 PADEP: 63-04247

435 Broad Street
 Montoursville, PA 17754
 P: (570) 321-9002
 F: (570) 321-1957
 PADEP: 41-04880

950 West Main Street
 Sharpville, PA 16150
 P: (724) 463-8378 x 500
 F: (724) 465-4209
 PADEP: 43-04934

Moniteau School District
 1810 West Sunbury Road
 West Sunbury, PA 16061

Reported: 07/23/2020 15:23

Lab Sample ID#: 0072234-01
Sample Type: Drinking Water
Sample Source: Grab
Sampler: Paul Somogyi
Client Sample ID: 804 Room 408 Sink

Sample Date: 07/23/2020 10:15
Receipt Date: 07/23/2020 13:30

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
Field Analysis	Analytical Method: SM4500-Cl G-11				Prep Method: No Prep - Field		
Chlorine, Free	0.600	mg/L		0.200	PFS	07/23/20 10:15	07/23/20 10:15

ENVIRONMENTAL SERVICE LABORATORIES, INC.

HEADQUARTER
1803 Philadelphia St.
Indiana, PA 15701
(724) 463-TEST
FAX: (724) 465-4209

SOUTHERN DIVISION
1276 Bentleyville Road
Van Voorhis, PA 15366
(724) 258-TEST
FAX: (724) 258-8376

NORTHERN DIVISION
435 Broad Street
Montoursville, PA 17754
(570) 321-9003
FAX: (570) 321-1957

NORTHWEST DIVISION
950 Main Street
Sharpsville, PA 16
(724) 463-TEST
FAX: (724) 465-4209



0072234

SAMPLE REQUEST & CHAIN OF CUSTODY

Page 3 of 4

FOR INTERNAL LABORATORY USE ONLY

Sample Identification Distribution: <u>804</u>	Sample Type Grab Date: <u>7-23-20</u> Time: <u>1015</u>	Matrix DW	# of Bottles Field	Container Type Preservative Field	Analysis Requested Free Chlorine <u>0.60</u> mg/L
	Sample Type Date: <u>7-23-20</u> Time: <u>1015</u>				
ROTATION Wk 1 - 801 Kitchen Sink Wk 2 - 802 Room 617 Sink Wk 3 - 803 Room 606 Sink Wk 4 - 804 Room 408 Sink Wk 5 - 802 Room 617 Sink					
Notes/Special Instructions: Drinking Water Dassa McKinney - Weekly					
Company/Name: MONITEAU SCHOOL DISTRICT Address: 391 HOOKER ROAD WEST SUNBURY, PA 16061 Contact Person: JEFFREY CAMPBELL Phone Number: 724-406-4426 Cell Phone: jcampbell@moniteau.k12.pa.us Email Address: jcampbell@moniteau.k12.pa.us Billing Address: 5100316 PWSID:					
Received By: (Signature) <u>[Signature]</u> Date/ Time <u>7/23/20 1330</u> Received By: (Signature) Date/ Time Received By: (Signature) Date/ Time Correct Preservations Y / N / NA Correct Containers Y / N / NA Receipt Temperature					
1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.) 2. THE UNDERSIGNED PURCHASER AGREES TO PAY FOR THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.					



E-Government Application for Drinking Water Program
 SAFE DRINKING WATER ACT
 VIEW/EDIT RECORDS

5100316: DASSA MCKINNEY ELEM SCHOOL
SDWA1

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100316	1013	FREE CHLORINE	301	0.49	070220	801		070220	D	1145	32382	0070252-01	BROWNKA_65
5100316	3100	TOTAL COLIFORM PRESENCE	331	0.0	070320	801		070220	D	1145	32382	0070252-01	BROWNKA_66
5100316	1013	FREE CHLORINE	301	0.44	070920	802		070920	D	1145	32382	0070921-01	BROWNKA_67
5100316	1013	FREE CHLORINE	301	0.52	071620	803		071620	D	1035	32382	0071605-01	BROWNKA_852
5100316	1013	FREE CHLORINE	301	0.6	072320	804		072320	D	1015	32382	0072234-01	BROWNKA_1546



1803 Philadelphia Street
 Indiana, PA 15701
 P: (724) 463-8378
 F: (724) 465-4209
 PADEP: 32-00382

1276 Bentleyville Road
 Van Voorhis, PA 15366
 P: (724) 258-8378
 F: (724) 258-8376
 PADEP: 63-04247

435 Broad Street
 Montoursville, PA 17754
 P: (570) 321-9002
 F: (570) 321-1957
 PADEP: 41-04880

950 West Main Street
 Sharpville, PA 16150
 P: (724) 463-8378 x 500
 F: (724) 465-4209
 PADEP: 43-04934

16 July 2020

Moniteau School District
 Attn: Jeffrey Campbell
 1810 West Sunbury Road
 West Sunbury, PA 16061

Work Order: 0071605
Project: Drinking Water Dassa McKinney - Weekly
Project Description: Drinking Water

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
803 Room 606 Sink	0071605-01	Drinking Water	07/16/2020 10:35	7/16/20 13:26	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

Approved By

Rebecca Erwin
 Project Manager



1803 Philadelphia Street
 Indiana, PA 15701
 P: (724) 463-8378
 F: (724) 465-4209
 PADEP: 32-00382

1276 Bentleyville Road
 Van Voorhis, PA 15366
 P: (724) 258-8378
 F: (724) 258-8376
 PADEP: 63-04247

435 Broad Street
 Montoursville, PA 17754
 P: (570) 321-9002
 F: (570) 321-1957
 PADEP: 41-04880

950 West Main Street
 Sharpsville, PA 16150
 P: (724) 463-8378 x 500
 F: (724) 465-4209
 PADEP: 43-04934

Moniteau School District
 1810 West Sunbury Road
 West Sunbury, PA 16061

Reported: 07/16/2020 14:33

Lab Sample ID#: 0071605-01
 Sample Type: Drinking Water
 Sample Source: Grab
 Sampler: Paul Somogyi
 Client Sample ID: 803 Room 606 Sink

Sample Date: 07/16/2020 10:35
 Receipt Date: 07/16/2020 13:26

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
Field Analysis	Analytical Method: SM4500-Cl G-11		Prep Method: No Prep - Field				
Chlorine, Free	0.520	mg/L		0.200	PFS	07/16/20 10:35	07/16/20 10:35

ENVIRONMENTAL SERVICE LABORATORIES, INC.

HEADQUARTER
1803 Philadelphia St.
Indiana, PA 15701
(724) 463-TEST
FAX: (724) 465-4209

SOUTHERN DIVISION
1276 Bentleyville Road
Van Voorhis, PA 15366
(724) 258-TEST
FAX: (724) 258-8376

NORTHERN DIVISION
435 Broad Street
Montoursville, PA 17754
(570) 321-9003
FAX: (570) 321-1957



0071605

FOR INTERNAL LABORATORY USE ONLY

Sample Identification	ESL#	Sample Type		Matrix	# of Bottles	Container Type Preservative	Analysis Requested
		Date	Time				
Distribution: <u>803</u>	<u>0071605</u>	<u>7/16/20</u>	<u>1035</u>	DW	Field	Field	Free Chlorine <u>1.52</u> mg/L
<div style="border: 1px solid black; padding: 5px;"> <p>ROTATION</p> <p>Wk 1 - 801 Kitchen Sink</p> <p>Wk 2 - 802 Room-617 Sink</p> <p>Wk 3 - 803 Room 606 Sink</p> <p>Wk 4 - 804 Room 408 Sink</p> <p>Wk 5 - 802 Room 617 Sink</p> </div>							

THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.

1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1.12% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.)

2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

Notes/Special Instructions: Drinking Water-Dassa-McKinney-Weekly

Company/Name: MONITEAU SCHOOL DISTRICT

Address: 391 HOOKER ROAD
WEST SUNBURY, PA 16061

Contact Person: JEFFREY CAMPBELL

Phone Number: 724-406-4426

Cell Phone: jcampbell@moniteau.k12.pa.us

Billing Address: 5100316

PWSID: 5100316

Received By: (Signature) [Signature] Date/ Time 7/16/20 1300

Relinquished By: (Signature) [Signature] Date/ Time 7/16/20 1035

Correct Preservations Y / N / NA Y / N / NA Correct Containers Y / N / NA Y / N / NA Receipt Temperature



E-Government Application for Drinking Water Program

SAFE DRINKING WATER ACT
VIEW/EDIT RECORDS

5100316: DASSA MCKINNEY ELEM SCHOOL

SDWA1

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100316	1013	FREE CHLORINE	301	0.49	070220	801		070220	D	1145	32382	0070252-01	BROWNKA_65
5100316	3100	TOTAL COLIFORM PRESENCE	331	0.0	070320	801		070220	D	1145	32382	0070252-01	BROWNKA_66
5100316	1013	FREE CHLORINE	301	0.44	070920	802		070920	D	1145	32382	0070921-01	BROWNKA_67
5100316	1013	FREE CHLORINE	301	0.52	071620	803		071620	D	1035	32382	0071605-01	BROWNKA_852



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

13 July 2020

Moniteau School District
Attn: Jeffrey Campbell
1810 West Sunbury Road
West Sunbury, PA 16061

Work Order: 0070921
Project: Drinking Water Dassa McKinney - Weekly
Project Description: Drinking Water

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
802 Room 617 Sink	0070921-01	Drinking Water	07/09/2020 11:45	7/9/20 15:12	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

Approved By

Rebecca Erwin
Project Manager



1803 Philadelphia Street
 Indiana, PA 15701
 P: (724) 463-8378
 F: (724) 465-4209
 PADEP: 32-00382

1276 Bentleyville Road
 Van Voorhis, PA 15366
 P: (724) 258-8378
 F: (724) 258-8376
 PADEP: 63-04247

435 Broad Street
 Montoursville, PA 17754
 P: (570) 321-9002
 F: (570) 321-1957
 PADEP: 41-04880

950 West Main Street
 Sharpville, PA 16150
 P: (724) 463-8378 x 500
 F: (724) 465-4209
 PADEP: 43-04934

Moniteau School District
 1810 West Sunbury Road
 West Sunbury, PA 16061

Reported: 07/13/2020 07:39

Lab Sample ID#: 0070921-01
Sample Type: Drinking Water
Sample Source: Grab
Sampler: Paul Somogyi
Client Sample ID: 802 Room 617 Sink

Sample Date: 07/09/2020 11:45
Receipt Date: 07/09/2020 15:12

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/Certification	Prep Date/Time	Analysis Date/Time
Field Analysis	Analytical Method: SM4500-Cl G-11				Prep Method: No Prep - Field		
Chlorine, Free	0.440	mg/L		0.200	PFS	07/09/20 11:45	07/09/20 11:45

ENVIRONMENTAL SERVICE LABORATORIES, INC.

HEADQUARTER
1803 Philadelphia St.
Indiana, PA 15701
(724) 463-TEST
FAX: (724) 465-4209

SOUTHERN DIVISION
1276 Bentleyville Road
Van Voorhis, PA 15366
(724) 258-TEST
FAX: (724) 258-8376

SAMPLE REQUEST & CHAIN OF CUSTODY

3E 1 OF 1

NORTHWEST DIVISION
50 Main Street
Harpsville, PA 16
(724) 463-TEST
FAX: (724) 465-4209



0070921

FOR INTERNAL LABORATORY USE ONLY

Sample Identification	ESL#	Sample Type		Matrix	# of Bottles	Container Type Preservative	Analysis Requested
		Grab	Time				
Distribution: <u>802</u>	<u>0070921</u>	Date: <u>7-9-20</u>	Time: <u>1145</u>	DW	Field	Field	Free Chlorine <u>1.44</u> mg/L
<p>ROTATION</p> <p>Wk 1 - 801 Kitchen Sink</p> <p>Wk 2 - 802 Room 617 Sink</p> <p>Wk 3 - 803 Room 606 Sink</p> <p>Wk 4 - 804 Room 408 Sink</p> <p>Wk 5 - 802 Room 617 Sink</p>							

Notes/Special Instructions:

Drinking Water Dassa McKinney - Weekly

Company/Name: **MONITEAU SCHOOL DISTRICT**
 Address: **3911 HOOKER ROAD**
WEST SUNBURY, PA 16061
 Contact Person: **JEFFREY CAMPBELL**
 Phone Number: **724-406-4426**
 Cell Phone: **jcampbell@moniteau.k12.pa.us**
 Billing Address:
 PWSID: **5100316**

1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.)
 2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, APPROPRIABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

Sampled By: (Signature) [Signature] Date/ Time 7-9-20 1145
 Relinquished By: (Signature) [Signature] Date/ Time 7-9-20 1400
 Relinquished By: (Signature) _____ Date/ Time _____
 Relinquished By: (Signature) _____ Date/ Time _____

Received By: (Signature) [Signature] Date/ Time 7/9/20 15:00
 Received By: (Signature) _____ Date/ Time _____
 Received By: (Signature) _____ Date/ Time _____

Correct Preservations Y / N (NA) Correct Containers Y / N (NA) Receipt Temperature -



E-Government Application for Drinking Water Program

SAFE DRINKING WATER ACT
VIEW/EDIT RECORDS

5100316: DASSA MCKINNEY ELEM SCHOOL

SDWA1

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100316	1013	FREE CHLORINE	301	0.49	070220	801		070220	D	1145	32382	0070252-01	BROWNKA_65
5100316	3100	TOTAL COLIFORM PRESENCE	331	0.0	070320	801		070220	D	1145	32382	0070252-01	BROWNKA_66
5100316	1013	FREE CHLORINE	301	0.44	070920	802		070920	D	1145	32382	0070921-01	BROWNKA_67



1803 Philadelphia Street
 Indiana, PA 15701
 P: (724) 463-8378
 F: (724) 465-4209
 PADEP: 32-00382

1276 Bentleyville Road
 Van Voorhis, PA 15366
 P: (724) 258-8378
 F: (724) 258-8376
 PADEP: 63-04247

435 Broad Street
 Montoursville, PA 17754
 P: (570) 321-9002
 F: (570) 321-1957
 PADEP: 41-04880

950 West Main Street
 Sharpsville, PA 16150
 P: (724) 463-8378 x 500
 F: (724) 465-4209
 PADEP: 43-04934

13 July 2020

Moniteau School District
 Attn: Jeffrey Campbell
 1810 West Sunbury Road
 West Sunbury, PA 16061

Work Order: 0070252
Project: Drinking Water Dassa McKinney - Monthly 801
Project Description: Drinking Water

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
801 Kitchen Sink	0070252-01	Drinking Water	07/02/2020 11:45	7/2/20 13:40	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

Environmental Service Laboratories, Inc., Indiana, PA/TNI Certification #32-00382

Approved By

Rebecca Erwin

Rebecca Erwin
 Project Manager





1803 Philadelphia Street
 Indiana, PA 15701
 P: (724) 463-8378
 F: (724) 465-4209
 PADEP: 32-00382

1276 Bentleyville Road
 Van Voorhis, PA 15366
 P: (724) 258-8378
 F: (724) 258-8376
 PADEP: 63-04247

435 Broad Street
 Montoursville, PA 17754
 P: (570) 321-9002
 F: (570) 321-1957
 PADEP: 41-04880

950 West Main Street
 Sharpville, PA 16150
 P: (724) 463-8378 x 500
 F: (724) 465-4209
 PADEP: 43-04934

Moniteau School District
 1810 West Sunbury Road
 West Sunbury, PA 16061

Reported: 07/13/2020 08:01

Lab Sample ID#: 0070252-01
Sample Type: Drinking Water
Sample Source: Grab
Sampler: Paul Somogyi
Client Sample ID: 801 Kitchen Sink

Sample Date: 07/02/2020 11:45
Receipt Date: 07/02/2020 13:40

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/Certification	Prep Date/Time	Analysis Date/Time
Field Analysis		Analytical Method: SM4500-Cl G-11			Prep Method: No Prep - Field		
Chlorine, Free	0.490	mg/L		0.200	PFS	07/02/20 11:45	07/02/20 11:45
Microbiology		Analytical Method: SM9223 B-04			Prep Method: No Prep - Micro		
Total Coliform	Absent	per 100 mL		1	DAA	07/02/20 15:28	07/03/20 17:02
E. Coli	Absent	per 100 mL		1	DAA	07/02/20 15:28	07/03/20 17:02

This sample MEETS current EPA and DEP bacteriological standards of no detectable coliform bacteria per 100 mL sample.

ENVIRONMENTAL SERVICE LABORATORIES, INC.

SAMPLE REQUEST & CHAIN OF CUSTODY

SE 1 OF 1

HEADQUARTER
1803 Philadelphia St.
Indiana, PA 15701
(724) 463-TEST
FAX: (724) 465-4209

SOUTHERN DIVISION
1276 Bentleyville Road
Van Voorhis, PA 15366
(724) 258-TEST
FAX: (724) 258-8376

NORTHERN DIVISION
435 Broad Street
Montoursville, PA 17754
(570) 321-9003
FAX: (570) 321-1957

NORTHWEST DIVISION
950 Main Street
Sharpsville, PA 16
(724) 463-TEST
FAX: (724) 465-4209



0070252

FOR INTERNAL LABORATORY USE ONLY

Sample Identification	ESL# 0070252	Sample Type	Matrix	# of Bottles	Container Type	Analysis Requested
801 KITCHEN SINK 802 ROOM 617-SINK	01	Date 7/20/20	DW	1	STERILE PLASTIC NA THIO	TC/EC Free Chlorine 1.99 mg/L
		Time 1145				4.8 mg/L

Rotation:
801: Jan, Mar, May, Jul, Sep,
Nov
802: Feb, Apr, Jun, Aug, Oct,
Dec

THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.

1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.)

2. THE UNDERSIGNED PURCHASER AGREES TO PAY IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION. REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

Drinking Water Dassa McKinney - Monthly

Company Name: MONITEAU SCHOOL DISTRICT

Address: 391 HOOKER ROAD
WEST SUNBURY, PA 16061
JEFFREY CAMPBELL

Contact Person: 724-406-4426
Phone Number: jcampbell@moniteau.k12.pa.us
Cell Phone: 5100316
Billing Address: PWSID:

Received By: (Signature) Date/ Time 7/2/20 1340

Relinquished By: (Signature) Date/ Time 7/20 1145

Correct Preservations Y / N / NA Correct Containers Y / N / NA Receipt Temperature



E-Government Application for Drinking Water Program

SAFE DRINKING WATER ACT

VIEW/EDIT RECORDS

5100316: DASSA MCKINNEY ELEM SCHOOL

SDWA1

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100316	1013	FREE CHLORINE	301	0.49	070220	801		070220	D	1145	32382	0070252-01	BROWNKA_65
5100316	3100	TOTAL COLIFORM PRESENCE	331	0.0	070320	801		070220	D	1145	32382	0070252-01	BROWNKA_66
5100316	1013	FREE CHLORINE	301	0.44	070920	802		070920	D	1145	32382	0070921-01	BROWNKA_67

**Moniteau School District
Maintenance Department
Monthly Operations Report for
July 2020**

**Moniteau High School
Wastewater Treatment Plant**

Moniteau High School
WASTEWATER TREATMENT PLANT
July 2020 Monthly Worksheet

FLOW	$91,325 \div 31 = 2,945.96$ GPD
UV	$127.6 \div 21 = 6.07$ Daily Avg.
PH	Low 6.56
	High 7.58
D.O.	Low 8.62
	High 9.80
TOTAL Nitrogen	$14.4 + 14.3 = 28.7 \div 2 = 14.35$
TSS	$5 + <5 = 2.50$
NITRATE / Nitrite	$12.7 + 12.7 = 25.4 \div 2 = 12.7$
PHOS.	$1.1 + 1.8 = 2.9 \div 2 = 1.45$
CBOD	$4.22 + <3.00 = 2.11$
Fecal	$<1 + <1 = <1$

Your eDMR Report Has Been Received For Permit No. PA0091341

From: depgreenporthelpdesk@state.pa.us

To: monwarrior2003@yahoo.com; monwarrior2003@yahoo.com; mcafoose92@hotmail.com

Date: Tuesday, August 11, 2020, 04:11 PM EDT

This email is to confirm that the following report was received by DEP through the eDMR system:

Facility Name: MONITEAU JR SR HIGH SCHOOL

Permit Number: PA0091341

Report Frequency: Monthly

Report Type: DMR

Reporting Period: 07/01/2020-07/31/2020

Report Due Date: 08/28/2020

Submitted By: Jeffrey Campbell

Submission Id: 220945

Submission Status: Received

Submission Type: Original

To view the details of this report, access the eDMR system through DEP's [GreenPort](#) and select the link for View/Revise Submitted.

DISCHARGE MONITORING REPORT (DMR)

NAME: MONITEAU SCH DIST
 ADDRESS: 1810 W SUNBURY RD, WEST SUNBURY, PA, 16061-1220
 FACILITY: MONITEAU JR SR HIGH SCHOOL
 LOCATION: 1810 W SUNBURY RD, WEST SUNBURY, PA, 16061-1220
 STAGE: Final Effluent

PA0091341
 PERMIT NUMBER

001
 OUTFALL NUMBER

Reporting Frequency: Monthly
 DMR Effective From: 07/01/2020
 DMR Effective To: 07/31/2020
 Permit Expires: 05/31/2022
 Permit Application Due: 12/02/2021
 No Discharge:

MONITORING PERIOD			
YEAR	MO	DAY	TO
2020	07	01	31

FROM

PARAMETER	SAMPLE MEASUREMENT	QUANTITY OR LOADING		QUANTITY OR CONCENTRATION				SAMPLING FREQUENCY	SAMPLING TYPE
		VALUE	UNITS	VALUE	UNITS	VALUE	UNITS		
Dissolved Oxygen (00300)	SAMPLE MEASUREMENT	***		8.62		***		1/week	Grab
	PERMIT REQUIREMENT	***		4.0 M/in		***		1/week	Grab
pH (00400)	SAMPLE MEASUREMENT	***		6.56		***	7.58	1/week	Grab
	PERMIT REQUIREMENT	***		6.0 M/in		***	9.0 Max	1/week	Grab
Total Suspended Solids (00530)	SAMPLE MEASUREMENT	***		***		***	2.50	2/month	Grab
	PERMIT REQUIREMENT	***		***		***	30 Avg Mo	2/month	Grab
Total Nitrogen (00600)	SAMPLE MEASUREMENT	***		***		***	14.35 Avg Mo	2/month	Grab
	PERMIT REQUIREMENT	***		***		***	Monitor & Report Avg Mo	2/month	Grab
Total Phosphorus (00665)	SAMPLE MEASUREMENT	***		***		***	1.45	2/month	Grab
	PERMIT REQUIREMENT	***		***		***	Monitor & Report Avg Mo	2/month	Grab
Ultraviolet light intensity (49607)	SAMPLE MEASUREMENT	***		***		***	6.07	1/week	Grab
	PERMIT REQUIREMENT	***		***		***	Monitor & Report Avg Mo	1/week	Grab
Flow (50050)	SAMPLE MEASUREMENT	.002945		***		***	***	1/week/day	Grab
	PERMIT REQUIREMENT	Monitor & Report Avg Mo	MGD	***		***	***	1/week	Measured

DISCHARGE MONITORING REPORT (DMR)

PARAMETER	SAMPLE MEASUREMENT	QUANTITY OR LOADING			QUANTITY OR CONCENTRATION				SAMPLING FREQUENCY	SAMPLING TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS		
Fecal Coliform (74055)	SAMPLE MEASUREMENT	***	***	***	<1.0	<1.0			2/month	Grab
	PERMIT REQUIREMENT	***	***	***	200	1000	IMAX	No./100 ml	2/month	Grab
Carbonaceous Biochemical Oxygen Demand (CBOD5) (80082)	SAMPLE MEASUREMENT	***	***	***	2.11	***			2/month	Grab
	PERMIT REQUIREMENT	***	***	***	25	Avg Mo	***	mg/L	2/month	Grab
Facility Comments										

COMMENT DETAILS

COMMENTS	OPERATOR NAME	OPERATOR CERTIFICATION NUMBER	OPERATOR CONTACT NUMBER
----------	---------------	-------------------------------	-------------------------



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

27 July 2020

Moniteau School District
Attn: Jeffrey Campbell
1810 West Sunbury Road
West Sunbury, PA 16061

Work Order: 0071612
Project: Wastewater
Project Description: Wastewater

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
Effluent Outfall 001	0071612-01	Waste Water	07/16/2020 10:30	7/16/20 13:00	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

TKN subcontracted to Suburban Water Testing Laboratory-Reading, PA DEP Lab ID 06-00208; please see attached subcontract laboratory Report of Analysis for results.

Definitions

- BB Dilution water blank exceeded method acceptance criteria of 0.20 mg/L DO loss.
- RL Reporting Limit
- CFU Colony Forming Units

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.
Environmental Service Laboratories, Inc., Indiana, PA/TNI Certification #32-00382

Approved By

Rebecca Erwin
Project Manager





1803 Philadelphia Street
 Indiana, PA 15701
 P: (724) 463-8378
 F: (724) 465-4209
 PADEP: 32-00382

1276 Bentleyville Road
 Van Voorhis, PA 15366
 P: (724) 258-8378
 F: (724) 258-8376
 PADEP: 63-04247

435 Broad Street
 Montoursville, PA 17754
 P: (570) 321-9002
 F: (570) 321-1957
 PADEP: 41-04880

950 West Main Street
 Sharpville, PA 16150
 P: (724) 463-8378 x 500
 F: (724) 465-4209
 PADEP: 43-04934

Moniteau School District
 1810 West Sunbury Road
 West Sunbury, PA 16061

Reported: 07/27/2020 19:25

Lab Sample ID#: 0071612-01
 Sample Type: Waste Water
 Sample Source: Grab
 Sampler: Client
 Client Sample ID: Effluent Outfall 001

Sample Date: 07/16/2020 10:30
 Receipt Date: 07/16/2020 13:00

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/Certification	Prep Date/Time	Analysis Date/Time
General Chemistry	Analytical Method: CALC				Prep Method: [CALC]		
Total Nitrogen	14.3	mg/L		0.520	DAA	07/21/20 17:04	07/22/20 14:43
General Chemistry	Analytical Method: SM2540 D-11				Prep Method: No Prep - WetChem		
Total Suspended Solids	<5	mg/L		5	LMB	07/21/20 09:46	07/21/20 11:45
General Chemistry	Analytical Method: SM4500-NO3 E-11 (discrete)				Prep Method: No Prep - WetChem		
Nitrate/Nitrite	12.7	mg/L		0.520	DAA	07/21/20 17:04	07/22/20 14:43
General Chemistry	Analytical Method: SM4500-P E-11				Prep Method: No Prep - WetChem		
Phosphorus	1.8	mg/L		1.0	JPD	07/18/20 12:02	07/18/20 13:00
General Chemistry	Analytical Method: SM5210 B-11				Prep Method: No Prep - WetChem		
Carbonaceous Biochemical Oxygen Demand	<3.00	mg/L	BB	3.00	AW	07/17/20 13:27	07/22/20 09:20
Microbiology	Analytical Method: Colilert-18				Prep Method: No Prep - Micro		
Fecal Coliforms	<1	MPN/100 mL		1	DAA	07/16/20 15:41	07/17/20 11:37

ENVIRONMENTAL SERVICE LABORATORIES, INC.

HEADQUARTERS
 1803 Philadelphia St.
 Indiana, PA 15701
 (724) 463-TEST
 FAX: (724) 465-4209

SAMPLE REQUEST & CHAIN OF CUSTODY

SOUTHERN DIVISION
 1276 Bentleyville Road
 Van Voorhis, PA 15366
 (724) 258-TEST
 FAX: (724) 258-8376

NORTHERN DIVISION
 0071612

NORTHWEST DIVISION
 950 Main Street
 Sharpsville, PA 16150
 (724) 463-TEST
 FAX: (724) 465-4209

FOR INTERNAL LAB USE

Sample Identification	ESL#	Sample Type		Date	Grab Time	# of Containers	Matrix	Container Type Preservative	Analysis Requested
		Composite Date on/off	Time on/off						
Effluent Outfall 001	021017			7/16/20	10:30 AM	1	WW	Poly 1000mL	CBOD, TSS
						1	WW	None	Total Nitrogen, Total Phosphorus
						1	WW	H2SO4	Fecal Coliform
								Sterile Plastic 125mL	3.02 #3 1300 B1
								Na2S2O3	

Project Notes:
 THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.
 1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.)
 2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

Wastewater

Company/Name: MONITEAU SCHOOL DISTRICT

Contact Person: JEFFREY CAMPBELL
 1810 WEST SUNBURY ROAD
 WEST SUNBURY, PA 16061
 724-406-4426
 jcampbell@moniteau.k12.pa.us

Received By: (Signature) [Signature] **Date/ Time** 7/16/20 10:50


Relinquished By: (Signature) [Signature] **Date/ Time** 7/16/20 10:50

Relinquished By: (Signature) [Signature] **Date/ Time** 7/16/20 10:30 AM

Received By: (Signature) [Signature] **Date/ Time** 7/16/20 12:58 1300

Relinquished By: (Signature) [Signature] **Date/ Time** 7/16/20 10:50

Correct Preservations Y / N / NA **Correct Containers** Y / N / NA **Receipt Temperature**



SAMPLE RECEIPT AND REVIEW FORM

PART A: General Information



0071612

Client: <u>Monitow</u>		Work Ord: _____	
Received by: <u>JBY</u>	Date/Time Received: <u>7/15/2</u> <u>1300</u>	Date Sampled: <u>7/15/2</u>	
Method of Delivery: FedEx UPS Client Drop off <u>ESL courier</u> Other: _____			
Sample Receipt Temp: <u>3.0</u>	Samples Received on Ice: <input checked="" type="radio"/> YES NO		
IR Gun # Used: 1 2 <u>(3)</u> 4			
Samples Removed by Satellite Lab Division: Southern(BV) NorthWest(NW) Northern(WP)	Containers removed by Satellite Lab for analysis of:	TCMPN	Fecal Coliform TC/EC
Sample State of Collection: <u>PA</u> NY OH WV Other: _____	PWSID COMPLIANCE DRINKING WATER SAMPLES: YES <input checked="" type="radio"/> NO		

PART B: Receipt Details

Completed (if different from above): _____ / _____ / _____
Signature Date Time

Sample Receipt Criteria				Comments/Qualifiers (Required for Non-Conforming Items)	Deficiency Log Required
1 Chain of custody documents included with samples?	Yes	No	N/A	Comments:	YES NO
2 COC form is properly signed in relinquished/received sections?	Yes	No	N/A	Comments:	YES NO
3 Sample containers intact and sealed?	Yes	No	N/A	Circle Applicable: Damaged container Leaking container Custody Seal Broken Other: _____	YES NO
4 Number of containers received match number indicated on COC?	Yes	No	N/A	Sample ID's affected:	YES NO
5 Sample ID's on COC match ID's on bottles?	Yes	No	N/A	Sample ID's and containers affected:	YES NO
6 Date and time on COC match date and time on bottles?	Yes	No	N/A	Sample ID's affected:	YES NO
7 Samples received within holding time?	Yes	No	N/A	ID's and tests affected:	YES NO
8 Samples received at appropriate pH for analysis requested?	Yes	No	N/A	Sample ID's, containers affected and observed pH:	YES NO
9 Samples requiring thermal preservation within 0 ≤ 6°C? Microbiology within 0 ≤ 10°C?	Yes	No	N/A	For non-WV samples outside of thermal preservation range sampled same day and received on ice are considered acceptable condition as the cooling process has begun.	YES NO
11 Adequate sample volume received?	Yes	No	N/A	Analyses Affected:	YES NO
10 VOA vials free of headspace (defined as < 6mm bubble)?	Yes	No	<u>N/A</u>	Sample ID's and containers affected:	YES NO
Other Comments:					Deficiency Log Created:
					Yes <input checked="" type="radio"/> No



Results Report

Order ID: 0074851

Environmental Service Laboratories, Inc.
1803 Philadelphia Street
Indiana, PA 15701

Project: TKN Testing

Attn: Accounts Payable

Regulatory ID:

Sample Number: 0074851-01
Collector: Client

Site: 0071612-01
Collect Date: 07/16/2020 10:30 am

Sample ID:
Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Inorganics										
Total Kjeldahl Nitrogen (TKN)	1.58	B	mg/L	EPA 351.2	0.50	1	07/23/20	ZJH	07/24/20 10:33	DWL

Data Qualifiers:

B The target analyte was detected in the Method, Dilution Water, Instrument or Extraction Blank or Sterility Check at or above the method Reporting Limit or applicable method, client, or regulatory requirement.

Sample Receipt Conditions:

All samples met the sample receipt requirements for the relevant analyses.

The test *pH, Lab* is performed in the Laboratory as soon as possible. These results are not appropriate for compliance with NPDES, SDWA, or other regulatory programs that require analysis within 15 minutes of sample collection and should be considered for informational purposes only.

**pH, Final* for ASTM leachate is performed by method SM 4500-H-B.

All results meet the requirements of STL's TNI (NELAC) Accredited Quality System unless otherwise noted. If your results contain any data qualifiers or comments, you should evaluate useability relative to your needs.

If collectors initials include "STL", samples have been collected in accordance with STL SOP SL0015.

All results reported on an As Received (Wet Weight) basis unless otherwise noted.

This laboratory report may not be reproduced, except in full, without the written approval of STL.

Results are considered Preliminary unless report is signed by authorized representative of STL.

Reviewed and Released By:

Ryan F Knerr
Project Manager II

Report Generated On: 07/24/2020 4:03 pm 0074851
STL_Results Revision #1.9 Effective: 04/16/2020



SUBCONTRACT ORI
Environmental Service Laborz
0071612



0074851
Lisa F. Care

Please report all results to reports@envlabs.com.

SENDING LABORATORY:

Environmental Service Laboratories, Inc.
1803 Philadelphia Street
Indiana, PA 15701
Phone: 724-463-8378
Fax: 724-465-4209
Project Manager: Rebecca Erwin

RECEIVING LABORATORY:

Suburban Water Testing Labs - Reading
1037F MacArthur Road
Reading, PA 19605
Phone: (610) 375-8378
Fax: 1610-375-4090

State of Origin: PA

Analysis	Due	Expires	Comments
Sample ID: 0071612-01			
Matrix: Water	Sampled: 07/16/2020 10:30	Sample Type: Grab	Sampled By: Client
Total Kjeldahl Nitrogen	07/28/2020 23:00	08/13/2020 10:30	
Containers Supplied: Poly 250mL, H2SO4 (D)			

*(1) 250 ml p & H2SO4
PhL2 & AH
7/17/20*

Suburban Testing Labs

Lab Date/Time: 7/17/20 1120 Lab Temp: 1.6 °C
 Number of containers/coolers match number on COC? Y N
 Sample labels and COC are free of discrepancies? Y N
 All containers in tact? Y N
 Received in lab within acceptable temperature limits? Y N
 40mL VOA vials free of headspace? Y N
 Relinquished by: Deliver
 Received in Lab by: RAH 1.6
we

Released By	Date	Received By	Date
Released By	Date	Received By	Date





JEFFREY CAMPBELL <jcampbell@moniteau.org>

Moniteau - Change Order Request 2

1 message

danzinkhann@rightelectric.com <danzinkhann@rightelectric.com>

Tue, Jul 28, 2020 at 11:56 AM

To: "James J. Carthew" <jcarthew@cjlengineering.com>, dgable@cjlengineering.com, JEFFREY CAMPBELL <jcampbell@moniteau.org>

Cc: Scott Straynick <sps@rightelectric.com>

Please see attached COR#2 to furnish and install 2 new primary transformer disconnect switches.

Thanks,

Dan Zinkhann

Right Electric, Inc.

(724) 482-2181



This email has been checked for viruses by Avast antivirus software.

www.avast.com



COR #2 Disconnect Switches.pdf

17K



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

21 July 2020

Moniteau School District
Attn: Jeffrey Campbell
1810 West Sunbury Road
West Sunbury, PA 16061

Work Order: 0070907
Project: Wastewater
Project Description: Wastewater

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
Effluent Outfall 001	0070907-01	Waste Water	07/09/2020 11:00	7/9/20 14:25	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

TKN subcontracted to Suburban Water Testing Laboratory-Reading, PA DEP Lab ID 06-00208; please see attached subcontract laboratory Report of Analysis for results.

Definitions

- BB Dilution water blank exceeded method acceptance criteria of 0.20 mg/L DO loss.
- RL Reporting Limit
- CFU Colony Forming Units

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.
Environmental Service Laboratories, Inc., Indiana, PA/TNI Certification #32-00382

Approved By

Rebecca Erwin
Project Manager





1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

Moniteau School District
1810 West Sunbury Road
West Sunbury, PA 16061

Reported: 07/21/2020 12:37

Lab Sample ID#: 0070907-01
Sample Type: Waste Water
Sample Source: Grab
Sampler: Client
Client Sample ID: Effluent Outfall 001

Sample Date: 07/09/2020 11:00
Receipt Date: 07/09/2020 14:25

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
General Chemistry	Analytical Method: CALC				Prep Method: [CALC]		
Total Nitrogen	14.4	mg/L		0.520	DAA	07/14/20 17:40	07/15/20 10:26
General Chemistry	Analytical Method: SM2540 D-11				Prep Method: No Prep - WetChem		
Total Suspended Solids	5	mg/L		5	TLL	07/14/20 07:36	07/14/20 14:50
General Chemistry	Analytical Method: SM4500-NO3 E-11 (discrete)				Prep Method: No Prep - WetChem		
Nitrate/Nitrite	12.7	mg/L		0.520	DAA	07/14/20 17:40	07/15/20 10:26
General Chemistry	Analytical Method: SM4500-P E-11				Prep Method: No Prep - WetChem		
Phosphorus	1.1	mg/L		0.20	JPD	07/16/20 11:02	07/16/20 12:00
General Chemistry	Analytical Method: SM5210 B-11				Prep Method: No Prep - WetChem		
Carbonaceous Biochemical Oxygen Demand	4.22	mg/L	BB	3.00	AW	07/10/20 13:15	07/15/20 09:20
Microbiology	Analytical Method: Colilert-18				Prep Method: No Prep - Micro		
Fecal Coliforms	<1	MPN/100 mL		1	DAA	07/09/20 15:42	07/10/20 13:26

**ENVIRONMENTAL SERVICE
LABORATORIES, INC.**

HEADQUARTERS
1803 Philadelphia St.
Indiana, PA 15701
(724) 463-TEST
FAX: (724) 465-4209

SOUTHERN DIVISION
1276 Bentleyville Road
Van Voorhis, PA 15366
(724) 258-TEST
FAX: (724) 258-8376

NORTHERN DIVISION
47
M
(5
F/

FOR INTERNAL LABORATORY USE

SAMPLE REQUEST & CHAIN OF CUSTODY

WEST DIVISION
Main Street
Parsippany, PA 16150
(724) 463-TEST
FAX: (724) 465-4209



Sample Identification	ESL#	Sample Type		Date	Time	Matrix	# of Containers	Container Type Preservative	Analysis Requested
		Composite	Grab						
Effluent Outfall 001	000001	Composite	Grab	7/9/20	11:00 AM	WW	1	Poly 1000mL	CBOD, TSS Total Nitrogen, Total Phosphorus Fecal Coliform
		Composite	Grab			WW	1	None	
		Composite	Grab			WW	1	H2SO4	
								Sterile Plastic 125mL Na2S2O3	

Project Notes:


Wastewater

Company/Name: **MONITEAU SCHOOL DISTRICT**
Contact Person: **JEFFREY CAMPBELL**
Address: **1810 WEST SUNBURY ROAD
WEST SUNBURY, PA 16061
724-406-4426**
Phone / Cell: **icampbell@moniteau.k12.pa.us**
Email:

THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.
1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.)
2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

Sampled By: (Signature) [Signature] Date/ Time 7/9/20 11:00 AM
Relinquished By: (Signature) [Signature] Date/ Time 7/9/20 11:55
Relinquished By: (Signature) [Signature] Date/ Time 7/9/20 14:00
Relinquished By: (Signature) [Signature] Date/ Time 7/9/20 11:30
Relinquished By: (Signature) [Signature] Date/ Time 7/9/20 11:55

Correct Preservations Y / N / NA Correct Containers Y / N / NA Receipt Temperature



SAMPLE RECEIPT AND REVIEW FORM

PART A: General Information

Client: <u>Munifew</u>		Work Order: <u>0070907</u>	
Received by: <u>DDP</u>		Date/Time Received: <u>7/9/12 11:35</u>	
Method of Delivery: <u>Fedex</u>		Other: _____	
Sample Receipt Temp: <u>4.2</u>		Samples Received on Ice: <u>YES</u>	
IR Gun # Used: <u>3</u>		NO	
Samples Removed by Satellite Lab Division: <u>NorthWest(NW) Northern(WP)</u>		Containers removed by <u>TCMPN</u>	
Sample State of Collection: <u>PA</u>		Satellite Lab for analysis of: <u>ECMPN</u>	
Other: _____		Fecal Coliform TC/EC	
PWSID COMPLIANCE DRINKING WATER SAMPLES: <u>NO</u>		YES	

PART B: Receipt Details

Completed (if different from above): _____ Signature: [Signature] Date: 7/9/12 Time: 14:30

Sample Receipt Criteria	Comments/Qualifiers (Required for Non-Conforming Items)	Deficiency Log Required
1 Chain of custody documents included with samples?	Comments: N/A	YES NO
2 COC form is properly signed in relinquished/received sections?	Comments: N/A	YES NO
3 Sample containers intact and sealed?	Circle Applicable: Damaged container Leaking container Custody Seal Broken Other: N/A	YES NO
4 Number of containers received match number indicated on COC?	Sample ID's affected: N/A	YES NO
5 Sample ID's on COC match ID's on bottles?	Sample ID's and containers affected: N/A	YES NO
6 Date and time on COC match date and time on bottles?	Sample ID's affected: N/A	YES NO
7 Samples received within holding time?	ID's and tests affected: N/A	YES NO
8 Samples received at appropriate pH for analysis requested?	Sample ID's, containers affected and observed pH: N/A	YES NO
9 Samples requiring thermal preservation within 0 ≤ 6°C? Microbiology within 0 ≤ 10°C?	For non-WV samples outside of thermal preservation range sampled same day and received on ice are considered acceptable condition as the cooling process has begun. N/A	YES NO
11 Adequate sample volume received?	Analyses Affected: N/A	YES NO
10 VOA vials free of headspace (defined as < 6mm bubble)?	Sample ID's and containers affected: N/A	YES NO
Other Comments:		Deficiency Log Created: <u>NO</u>



Results Report

Order ID: 0073398

Environmental Service Laboratories, Inc. 1803 Philadelphia Street Indiana, PA 15701	Project: TKN Testing
Attn: Accounts Payable	Regulatory ID:

Sample Number: 0073398-01	Site: 0070907-01	Sample ID: 0070907
Collector: Client	Collect Date: 07/09/2020 11:00 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Inorganics										
Total Kjeldahl Nitrogen (TKN)	1.68	B	mg/L	EPA 351.2	0.50	1	07/20/20	ZJH	07/20/20 13:58	DWL

Data Qualifiers:

B The target analyte was detected in the Method, Dilution Water, Instrument or Extraction Blank or Sterility Check at or above the method Reporting Limit or applicable method, client, or regulatory requirement.

Sample Receipt Conditions:

All samples met the sample receipt requirements for the relevant analyses.

The test *pH, Lab* is performed in the Laboratory as soon as possible. These results are not appropriate for compliance with NPDES, SDWA, or other regulatory programs that require analysis within 15 minutes of sample collection and should be considered for informational purposes only.

**pH, Final* for ASTM leachate is performed by method SM 4500-H-B.

All results meet the requirements of STL's TNI (NELAC) Accredited Quality System unless otherwise noted. If your results contain any data qualifiers or comments, you should evaluate useability relative to your needs.

If collectors initials include "STL", samples have been collected in accordance with STL SOP SL0015.

All results reported on an As Received (Wet Weight) basis unless otherwise noted.

This laboratory report may not be reproduced, except in full, without the written approval of STL.

Results are considered Preliminary unless report is signed by authorized representative of STL.

Reviewed and Released By:

Lisa F. Care
Project Manager I

Report Generated On: 07/21/2020 10:57 am 0073398
STL_Results Revision #1.9 Effective: 04/16/2020



**Moniteau School District
Maintenance Department
Monthly Operations Report for
July 2020**

**Moniteau High School
Water Treatment Plant**

MONTH		MONITEAU HIGH SCHOOL WATER TREATMENT PLANT										
DAY	TEMP	LEVEL	METER READING	CL2 FREE	CL2 TOTAL	PH	IRON	MAG.	HARDNESS	OPERATOR	TIME	
1	Wed	69.0	3,565, 180	0.81	0.91	7.4	0.03	0	0.90	Jeff C	1:30 AM	
2	Thurs	72.4	3,565, 180	0.80	0.90	7.4	0.02	0	0.91	Jeff C	7:30 AM	
3	Fri		Holiday		Closed							
4	SAT											
5	SUN											
6	Mon	74.5	3,586, 346	0.76	0.80	7.4	0.01	0	0.95	Jeff C	7:30 AM	
7	Tues	75.0	3,594, 510	0.75	0.81	7.4	0.00	0	0.97	Jeff C	2:00 PM	
8	Wed	75.7	3,594, 510	0.75	0.80	7.4	0.00	0	0.97	Jeff C	7:00 AM	
9	Thurs	71.4	3,606, 956	0.77	0.88	7.3	0.02	0	2.11	Jeff C	8:00 AM	
10	Fri	72.0	3,606, 956	0.77	0.85	7.3	0.02	0	2.02	Jeff C	10:00 AM	
11	SAT											
12	SUN											
13	Mon	72.5	3,618, 774	0.76	0.87	7.3	0.01	0	1.86	Jeff C	1:00 PM	
14	Tues	70.2	3,627, 332	0.59	0.77	7.3	0.00	0	2.00	Jeff C	1:45 PM	
15	Wed	70.1	3,631, 506	0.62	0.78	7.3	0.00	0	2.02	Jeff C	11:00 AM	
16	Thurs	72.0	3,631, 506	0.54	0.66	7.3	0.00	0	1.21	Jeff C	11:00 AM	
17	Fri	74.7	3,631, 506	0.52	0.64	7.3	0.00	0	1.28	Jeff C	1:00 PM	
18	SAT											
19	SUN											
20	Mon	71.1	3,641, 829	0.97	1.01	7.3	0.00	0	0.99	Jeff C	06:30 AM	
21	Tues	74.1	3,641, 829	0.81	0.91	7.2	0.00	0	0.94	Jeff C	2:45 PM	
22	Wed	75.5	3,641, 829	0.80	0.90	7.2	0.00	0	0.95	Jeff C	1:00 PM	
23	Thurs	77.0	3,641, 829	0.82	0.93	7.2	0.00	0	0.92	Jeff C	4:00 PM	
24	Fri	77.4	3,641, 829	0.83	0.93	7.2	0.00	0	0.92	Jeff C	9:00 AM	
25	SAT											
26	SUN											
27	Mon	80.8	3,641, 829	0.41	0.53	7.3	0.00	0	0.96	Jeff C	10:30 AM	
28	Tues	72.0	3,656, 505	0.55	0.61	7.3	0.00	0	0.95	Jeff C	2:00 PM	
29	Wed	73.4	3,656, 505	0.43	0.51	7.4	0.02	0	0.96	Jeff C	1:00 PM	
30	Thurs	75.0	3,656, 505	0.38	0.44	7.5	0.02	0	0.98	Jeff C	9:00 AM	
31	Fri	77.0	3,656, 505	0.39	0.45	7.4	0.02	0	0.98	Jeff C	10:00 AM	

█ = ESL Test Day

6/30/2020 Meter Reading 3,565, 180



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

30 July 2020

Moniteau School District
Attn: Jeffrey Campbell
1810 West Sunbury Road
West Sunbury, PA 16061

Work Order: 0072767
Project: Drinking Water Moniteau Jr/Sr - Weekly
Project Description: Drinking Water

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
804 400 Hall RR Sink	0072767-01	Drinking Water	07/30/2020 10:10	7/30/20 12:56	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

Approved By

Rebecca Erwin
Project Manager



1803 Philadelphia Street
 Indiana, PA 15701
 P: (724) 463-8378
 F: (724) 465-4209
 PADEP: 32-00382

1276 Bentleyville Road
 Van Voorhis, PA 15366
 P: (724) 258-8378
 F: (724) 258-8376
 PADEP: 63-04247

435 Broad Street
 Montoursville, PA 17754
 P: (570) 321-9002
 F: (570) 321-1957
 PADEP: 41-04880

950 West Main Street
 Sharpsville, PA 16150
 P: (724) 463-8378 x 500
 F: (724) 465-4209
 PADEP: 43-04934

Moniteau School District
 1810 West Sunbury Road
 West Sunbury, PA 16061

Reported: 07/30/2020 13:27

Lab Sample ID#: 0072767-01
Sample Type: Drinking Water
Sample Source: Grab
Sampler: Paul Somogyi
Client Sample ID: 804 400 Hall RR Sink

Sample Date: 07/30/2020 10:10
Receipt Date: 07/30/2020 12:56

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
Field Analysis	Analytical Method: SM4500-Cl G-11				Prep Method: No Prep - Field		
Chlorine, Free	0.390	mg/L		0.200	PFS	07/30/20 10:10	07/30/20 10:10

ENVIRONMENTAL SERVICE LABORATORIES, INC.

HEADQUARTER
1803 Philadelphia St.
Indiana, PA 15701
(724) 463-TEST
FAX: (724) 465-4209

SOUTHERN DIVISION
1276 Bentleyville Road
Van Voorhis, PA 15366
(724) 258-TEST
FAX: (724) 258-8376

NORTHERN DIVISION
435 Broad St
Montoursville
(570) 321-91
FAX: (570)



FOR INTERNAL LABORATORY USE

SAMPLE REQUEST & CHAIN OF CUSTODY

3E 1 OF 1

Sample Identification	ESL#	Sample Type		Matrix	# of Bottles	Container Type Preservative	Analysis Requested
		Date	Time				
Distribution: <u>804</u>	<u>0072767</u>	<u>7-30-20</u>	<u>1010</u>	DW	Field	Field	Free Chlorine <u>39</u> mg/L
<p>ROTATION</p> <p>Wk 1 - 704 Kitchen Sink</p> <p>Wk 2 - 802 Room 204 Sink</p> <p>Wk 3 - 803 Admin Sink</p> <p>Wk 4 - 804 400 Hall-RR Sink</p> <p>Wk 5 - 804 400 Hall RR Sink</p>							
<p>Notes/Special Instructions:</p> <p>Drinking Water Moniteau Jr/Sr - Weekly</p>							
<p>Company/Name: MONITEAU SCHOOL DISTRICT</p> <p>Address: 391 HOOKER ROAD WEST SUNBURY, PA 16061 JEFFREY CAMPBELL</p> <p>Contact Person: 724-406-4426</p> <p>Phone Number: jcampbell@moniteau.k12.pa.us</p> <p>Cell Phone: 5100324</p> <p>Email Address:</p> <p>Billing Address:</p> <p>PWSID:</p>				<p>Received By: (Signature) <u>[Signature]</u> Date/ Time <u>7-30-20 12:50</u></p> <p>Received By: (Signature) Date/ Time</p> <p>Received By: (Signature) Date/ Time</p> <p>Received By: (Signature) Date/ Time</p>			
<p>Sampled By: (Signature) <u>[Signature]</u> Date/ Time <u>7-30-20 1010</u></p>				<p>Correct Containers <u>Y/N/NA</u> Receipt Temperature <u>—</u></p>			
<p>1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1.12% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.)</p> <p>2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.</p>							

5100324: MONITEAU JR/SR HIGH SCHOOL

SDWA1

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100324	1013	FREE CHLORINE	301	0.91	070220	704		070220	D	1157	32382	0070251-01	BROWNKA_68
5100324	3100	TOTAL COLIFORM PRESENCE	331	0.0	070320	704		070220	D	1157	32382	0070251-01	BROWNKA_69
5100324	1013	FREE CHLORINE	301	0.79	070920	802		070920	D	1155	32382	0070920-01	BROWNKA_70
5100324	1013	FREE CHLORINE	301	0.7	071620	803		071620	D	1047	32382	0071614-01	BROWNKA_853
5100324	1013	FREE CHLORINE	301	0.95	072320	804		072320	D	1030	32382	0072235-01	BROWNKA_1547
5100324	1013	FREE CHLORINE	301	0.39	073020	804		073020	D	1010	32382	0072767-01	BROWNKA_2043



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

23 July 2020

Moniteau School District
Attn: Jeffrey Campbell
1810 West Sunbury Road
West Sunbury, PA 16061

Work Order: 0072235
Project: Drinking Water Moniteau Jr/Sr - Weekly
Project Description: Drinking Water

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
804 400 Hall RR Sink	0072235-01	Drinking Water	07/23/2020 10:30	7/23/20 13:30	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

Approved By

Rebecca Erwin
Project Manager



1803 Philadelphia Street
 Indiana, PA 15701
 P: (724) 463-8378
 F: (724) 465-4209
 PADEP: 32-00382

1276 Bentleyville Road
 Van Voorhis, PA 15366
 P: (724) 258-8378
 F: (724) 258-8376
 PADEP: 63-04247

435 Broad Street
 Montoursville, PA 17754
 P: (570) 321-9002
 F: (570) 321-1957
 PADEP: 41-04880

950 West Main Street
 Sharpsville, PA 16150
 P: (724) 463-8378 x 500
 F: (724) 465-4209
 PADEP: 43-04934

Moniteau School District
 1810 West Sunbury Road
 West Sunbury, PA 16061

Reported: 07/23/2020 15:23

Lab Sample ID#: 0072235-01
Sample Type: Drinking Water
Sample Source: Grab
Sampler: Paul Somogyi
Client Sample ID: 804 400 Hall RR Sink

Sample Date: 07/23/2020 10:30
Receipt Date: 07/23/2020 13:30

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
Field Analysis	Analytical Method: SM4500-Cl G-11		Prep Method: No Prep - Field				
Chlorine, Free	0.950	mg/L		0.200	PFS	07/23/20 10:30	07/23/20 10:30

ENVIRONMENTAL SERVICE LABORATORIES, INC.

HEADQUARTER
1803 Philadelphia St.
Indiana, PA 15701
(724) 463-TEST
FAX: (724) 465-4209

SOUTHERN DIVISION
1276 Beniteyville Road
Van Voorhis, PA 15366
(724) 258-TEST
FAX: (724) 258-8376

NORTHERN DIVISION
435 Broad Street
Montoursville, PA 17754
(570) 321-9003
FAX: (570) 321-1957

NORTHWEST DIVISION
950 Main Street
Sharpsville, PA 16
(724) 463-TEST
FAX: (724) 465-4209



0072235

3E 1 OF 1

FOR INTERNAL LABORATORY USE ONLY

Sample Identification	ESL# 0072235	Sample Type	Matrix	# of Bottles	Container Type Preservative	Analysis Requested
Distribution: 804	01	Date 7-23-20	Time 1030	DW	Field	Free Chlorine 95 mg/L

ROTATION

- Wk 1 - 704 Kitchen Sink
- Wk 2 - 802 Room 204 Sink
- Wk 3 - 803 Admin Sink
- Wk 4 - 804 400 Hall RR Sink
- Wk 5 - 804 400 Hall RR Sink

THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.

- THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.)
- THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

Sampled By: (Signature) Date/ Time 7-23-20 1030

Relinquished By: (Signature) Date/ Time 7-23-20 1053

Received By: (Signature) Date/ Time 7/23/20 1330

Received By: (Signature) Date/ Time

Received By: (Signature) Date/ Time

Correct Preservations Y / N / NA Correct Containers Y / N / NA Receipt Temperature

Notes/Special Instructions:

Drinking Water Moniteau Jr/Sr - Weekly

Company/Name: MONITEAU SCHOOL DISTRICT
Address: 391 HOOKER ROAD
WEST SUNBURY, PA 16061
Contact Person: JEFFREY CAMPBELL
Phone Number: 724-406-4426
Cell Phone: jcampbell@moniteau.k12.pa.us
Billing Address: 5100324
PWSID:



E-Government Application for Drinking Water Program

SAFE DRINKING WATER ACT
VIEW/EDIT RECORDS

**5100324: MONITEAU JR/SR HIGH SCHOOL
SDWA1**

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100324	1013	FREE CHLORINE	301	0.91	070220	704		070220	D	1157	32382	0070251-01	BROWNKA_68
5100324	3100	TOTAL COLIFORM PRESENCE	331	0.0	070320	704		070220	D	1157	32382	0070251-01	BROWNKA_69
5100324	1013	FREE CHLORINE	301	0.79	070920	802		070920	D	1155	32382	0070920-01	BROWNKA_70
5100324	1013	FREE CHLORINE	301	0.7	071620	803		071620	D	1047	32382	0071614-01	BROWNKA_853
5100324	1013	FREE CHLORINE	301	0.95	072320	804		072320	D	1030	32382	0072235-01	BROWNKA_1547



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

16 July 2020

Moniteau School District
Attn: Jeffrey Campbell
1810 West Sunbury Road
West Sunbury, PA 16061

Work Order: 0071614
Project: Drinking Water Moniteau Jr/Sr - Weekly
Project Description: Drinking Water

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
803	0071614-01	Drinking Water	07/16/2020 10:47	7/16/20 13:00	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

Approved By

Rebecca Erwin
Project Manager



1803 Philadelphia Street
 Indiana, PA 15701
 P: (724) 463-8378
 F: (724) 465-4209
 PADEP: 32-00382

1276 Bentleyville Road
 Van Voorhis, PA 15366
 P: (724) 258-8378
 F: (724) 258-8376
 PADEP: 63-04247

435 Broad Street
 Montoursville, PA 17754
 P: (570) 321-9002
 F: (570) 321-1957
 PADEP: 41-04880

950 West Main Street
 Sharpsville, PA 16150
 P: (724) 463-8378 x 500
 F: (724) 465-4209
 PADEP: 43-04934

Moniteau School District
 1810 West Sunbury Road
 West Sunbury, PA 16061

Reported: 07/16/2020 14:33

Lab Sample ID#: 0071614-01
Sample Type: Drinking Water
Sample Source: Grab
Sampler: Paul Somogyi
Client Sample ID: 803

Sample Begin Date: 07/16/2020 00:00
Sample End Date: 07/16/2020 10:47
Receipt Date: 07/16/2020 13:00

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
Field Analysis	Analytical Method: SM4500-Cl G-11			Prep Method: No Prep - Field			
Chlorine, Free	0.700	mg/L		0.200	PFS	07/16/20 10:47	07/16/20 10:47

ENVIRONMENTAL SERVICE LABORATORIES, INC.

HEADQUARTER
1803 Philadelphia St.
Indiana, PA 15701
(724) 463-TEST
FAX: (724) 465-4209

SOUTHERN DIVISION
1276 Benleyville Road
Van Voorhis, PA 15366
(724) 258-TEST
FAX: (724) 258-8376

NORTHERN DIVISION
435 Broad Street
Montoursville, PA 17754
(570) 321-9003
FAX: (570) 321-1957

NORTHWEST DIVISION
950 Main Street
Sharpville, PA 16
(724) 463-TEST
FAX: (724) 465-4209

SAMPLE REQUEST & CHAIN OF CUSTODY

3E 1 OF 1



0071614

FOR INTERNAL LABORATORY USE ONLY

Sample Identification	ESL#	Sample Type		Matrix	# of Bottles	Container Type Preservative	Analysis Requested
		Grab	Time				
Distribution: 803	0071614		1047	DW	Field	Field	Free Chlorine 70 mg/L
	01						

- ROTATION
- Wk 1 - 704 Kitchen Sink
 - Wk 2 - 802 Room 204 Sink
 - Wk 3 - 803 Admin Sink
 - Wk 4 - 804 400 Hall RR Sink
 - Wk 5 - 804 400 Hall RR Sink

THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.

- THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1.12% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.)
- THE UNDERSIGNED PURCHASER AGREES TO PAY IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION. REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

Sampled By: (Signature) Date/ Time 7/16/20 1047

Relinquished By: (Signature) Date/ Time 7/16/20 1450

Received By: (Signature) Date/ Time 7/16/20 1300

Received By: (Signature) Date/ Time

Received By: (Signature) Date/ Time

Correct Preservations Y / N / NA Correct Containers Y / N / NA Receipt Temperature

Notes/Special Instructions ::

Drinking Water Moniteau Jr/Sr - Weekly

Company/Name: MONITEAU SCHOOL DISTRICT

Address: 391 HOOKER ROAD
WEST SUNBURY, PA 16061
JEFFREY CAMPBELL

Contact Person: 724-406-4426
Phone Number: jcampbell@moniteau.k12.pa.us
Cell Phone: 5100324
Email Address: 5100324
Billing Address: PWSID:



E-Government Application for Drinking Water Program

SAFE DRINKING WATER ACT
VIEW/EDIT RECORDS

5100324: MONITEAU JR/SR HIGH SCHOOL

SDWA1

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100324	1013	FREE CHLORINE	301	0.91	070220	704		070220	D	1157	32382	0070251-01	BROWNKA_68
5100324	3100	TOTAL COLIFORM PRESENCE	331	0.0	070320	704		070220	D	1157	32382	0070251-01	BROWNKA_69
5100324	1013	FREE CHLORINE	301	0.79	070920	802		070920	D	1155	32382	0070920-01	BROWNKA_70
5100324	1013	FREE CHLORINE	301	0.7	071620	803		071620	D	1047	32382	0071614-01	BROWNKA_853



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

13 July 2020

Moniteau School District
Attn: Jeffrey Campbell
1810 West Sunbury Road
West Sunbury, PA 16061

Work Order: 0070920
Project: Drinking Water Moniteau Jr/Sr - Weekly
Project Description: Drinking Water

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
802 Room 204 Sink	0070920-01	Drinking Water	07/09/2020 11:55	7/9/20 15:11	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

Approved By

Rebecca Erwin
Project Manager



1803 Philadelphia Street
 Indiana, PA 15701
 P: (724) 463-8378
 F: (724) 465-4209
 PADEP: 32-00382

1276 Bentleyville Road
 Van Voorhis, PA 15366
 P: (724) 258-8378
 F: (724) 258-8376
 PADEP: 63-04247

435 Broad Street
 Montoursville, PA 17754
 P: (570) 321-9002
 F: (570) 321-1957
 PADEP: 41-04880

950 West Main Street
 Sharpsville, PA 16150
 P: (724) 463-8378 x 500
 F: (724) 465-4209
 PADEP: 43-04934

Moniteau School District
 1810 West Sunbury Road
 West Sunbury, PA 16061

Reported: 07/13/2020 07:40

Lab Sample ID#: 0070920-01
Sample Type: Drinking Water
Sample Source: Grab
Sampler: Paul Somogyi
Client Sample ID: 802 Room 204 Sink

Sample Date: 07/09/2020 11:55
Receipt Date: 07/09/2020 15:11

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/Certification	Prep Date/Time	Analysis Date/Time
Field Analysis		Analytical Method: SM4500-Cl G-11			Prep Method: No Prep - Field		
Chlorine, Free	0.790	mg/L		0.200	PFS	07/09/20 11:55	07/09/20 11:55

ENVIRONMENTAL SERVICE LABORATORIES, INC.

HEADQUARTER
1803 Philadelphia St.
Indiana, PA 15701
(724) 463-TEST
FAX: (724) 465-4209

SOUTHERN DIVISION
1276 Benetleyville Road
Van Voorhis, PA 15366
(724) 258-TEST
FAX: (724) 258-3376



EST DIVISION
Street
P. PA 16
TEST
(4) 465-4209

SAMPLE REQUEST & CHAIN OF CUSTODY

SE 1 OF 1

FOR INTERNAL LABORATORY USE ONLY

Sample Identification	ESL#	Sample Type		Matrix	# of Bottles	Container Type	Analysis Requested
		Date	Time				
Distribution: <u>802</u>	<u>0070920</u>	<u>7-9-80</u>	<u>11:55</u>	DW	Field	Field	Free Chlorine <u>79</u> mg/L

ROTATION
 Wk 1 - 704 Kitchen Sink
Wk 2 - 802 Room 204 Sink
 Wk 3 - 803 Admin Sink
 Wk 4 - 804 400 Hall RR Sink
 Wk 5 - 804 400 Hall RR Sink

THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.

- THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.)
- THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

Sampled By: (Signature) [Signature] Date/ Time 7-9-80 11:55
 Relinquished By: (Signature) [Signature] Date/ Time 7-9-80 14:00

Relinquished By: (Signature) _____ Date/ Time _____
 Relinquished By: (Signature) _____ Date/ Time _____

Correct Preservations Y/N/NA Y/N/NA Correct Containers Y/N/NA Y/N/NA Receipt Temperature ✓

Notes/Special Instructions:

Drinking Water Moniteau Jr/Sr - Weekly

Company/Name: **MONITEAU SCHOOL DISTRICT**
 Address: **391 HOOKER ROAD
 WEST SUNBURY, PA 16061
 JEFFREY CAMPBELL**
 Contact Person:
 Phone Number:
 Cell Phone: **724-406-4426**
 Email Address: **jcampbell@moniteau.k12.pa.us**
 Billing Address:
 PWSID: **5100324**

5100324: MONITEAU JR/SR HIGH SCHOOL

SDWA1

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100324	1013	FREE CHLORINE	301	0.91	070220	704		070220	D	1157	32382	0070251-01	BROWNKA_68
5100324	3100	TOTAL COLIFORM PRESENCE	331	0.0	070320	704		070220	D	1157	32382	0070251-01	BROWNKA_69
5100324	1013	FREE CHLORINE	301	0.79	070920	802		070920	D	1155	32382	0070920-01	BROWNKA_70



1803 Philadelphia Street
 Indiana, PA 15701
 P: (724) 463-8378
 F: (724) 465-4209
 PADEP: 32-00382

1276 Bentleyville Road
 Van Voorhis, PA 15366
 P: (724) 258-8378
 F: (724) 258-8376
 PADEP: 63-04247

435 Broad Street
 Montoursville, PA 17754
 P: (570) 321-9002
 F: (570) 321-1957
 PADEP: 41-04880

950 West Main Street
 Sharpville, PA 16150
 P: (724) 463-8378 x 500
 F: (724) 465-4209
 PADEP: 43-04934

13 July 2020

Moniteau School District
 Attn: Jeffrey Campbell
 1810 West Sunbury Road
 West Sunbury, PA 16061

Work Order: 0070251
Project: Drinking Water Moniteau Jr/Sr - Monthly 704
Project Description: Drinking Water

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
704 Kitchen Main Sink	0070251-01	Drinking Water	07/02/2020 11:57	7/2/20 13:40	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.
 Environmental Service Laboratories, Inc., Indiana, PA/TNI Certification #32-00382

Approved By

Rebecca Erwin
 Project Manager





1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

Moniteau School District
1810 West Sunbury Road
West Sunbury, PA 16061

Reported: 07/13/2020 08:01

Lab Sample ID#: 0070251-01
Sample Type: Drinking Water
Sample Source: Grab
Sampler: Paul Somogyi
Client Sample ID: 704 Kitchen Main Sink

Sample Date: 07/02/2020 11:57
Receipt Date: 07/02/2020 13:40

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
Field Analysis		Analytical Method: SM4500-CI G-11			Prep Method: No Prep - Field		
Chlorine, Free	0.910	mg/L		0.200	PFS	07/02/20 11:57	07/02/20 11:57
Microbiology		Analytical Method: SM9223 B-04			Prep Method: No Prep - Micro		
Total Coliform	Absent	per 100 mL		1	DAA	07/02/20 15:28	07/03/20 17:02
E. Coli	Absent	per 100 mL		1	DAA	07/02/20 15:28	07/03/20 17:02

This sample MEETS current EPA and DEP bacteriological standards of no detectable coliform bacteria per 100 mL sample.

ENVIRONMENTAL SERVICE LABORATORIES, INC.

SAMPLE REQUEST & CHAIN OF CUSTODY

HEADQUARTER
1803 Philadelphia St.
Indiana, PA 15701
(724) 463-TEST
FAX: (724) 465-4209

SOUTHERN DIVISION
1276 Beniteville Road
Van Voorhis, PA 15366
(724) 258-TEST
FAX: (724) 258-8376

NORTHERN DIVISION
435 Broad Street
Montoursville, PA 17754
(570) 321-9003
FAX: (570) 321-1957

NORTHWEST DIVISION
950 Main Street
Sharpsville, PA 16150
(724) 463-TEST
FAX: (724) 465-4209



FOR INTERNAL LABORATORY USE ONLY

Sample Identification	ESL#	0070251	Matrix	# of Bottles	Container Type Preservative	Analysis Requested
	CIRCLE ONE: 704 KITCHEN MAIN SINK 802 ROOM 204 SINK	01				
Sample Type		Date	Time			
Grab		7-2-20	1157	4.8°C #310		

704: Jan, Mar, May, Jul, Sept, Nov
802: Feb, Apr, Jun, Aug, Oct, Dec

THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.

1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1.12% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.)
2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

Drinking Water Moniteau Jr/Sr - Monthly

Company Name: MONITEAU SCHOOL DISTRICT
Address: 1810 WEST SUNBURY ROAD
WEST SUNBURY, PA 16061
JEFFREY CAMPBELL
Phone Number: 724-406-4426
Cell Phone: jcampbell@moniteau.k12.pa.us
Billing Address: 5100324
PWSID: 5100324

Received By: (Signature) [Signature] Date/ Time 7-2-20 1157
Received By: (Signature) [Signature] Date/ Time 7-2-20 1338
Received By: (Signature) [Signature] Date/ Time 7-2-20 1340
Received By: (Signature) [Signature] Date/ Time [Signature] Date/ Time [Signature] Date/ Time [Signature] Date/ Time

Correct Preservations Y / N / NA Correct Containers Y / N / NA Receipt Temperature



E-Government Application for Drinking Water Program

SAFE DRINKING WATER ACT
VIEW/EDIT RECORDS

5100324: MONITEAU JR/SR HIGH SCHOOL

SDWA1

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100324	1013	FREE CHLORINE	301	0.91	070220	704		070220	D	1157	32382	0070251-01	BROWNKA_68
5100324	3100	TOTAL COLIFORM PRESENCE	331	0.0	070320	704		070220	D	1157	32382	0070251-01	BROWNKA_69
5100324	1013	FREE CHLORINE	301	0.79	070920	802		070920	D	1155	32382	0070920-01	BROWNKA_70